

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|---|--|--|---|---|----------------------------------|---------------------------------|
| 1. Location of well: | | County <u>Stevens</u> | Fraction <u>SE 1/4 SE 1/4 NE 1/4</u> | Section number <u>14</u> | Township number T <u>34</u> S | Range number R <u>37</u> E/W |
| 2. Distance and direction from nearest town or city: <u>16 W. 3 N. 1 E. 8 N. of Liberal, Ks.</u> Street address of well location if in city: | | | | 3. Owner of well: <u>Robert Gregg</u> R.R. or street: <u>Rt 1 Box 678</u> City, state, zip code: <u>Hugoton, Ks 67951</u> | | |
| 4. Locate with "X" in section below: N 1 Mile W E S 1 Mile | | Sketch map: | | 6. Bore hole dia. <u>9</u> in. Completion date <u>2/9/77</u> Well depth <u>340</u> ft. | | |
| | | 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| | | 9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>14</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>14</u> lbs./ft. Dia. <u>5</u> in. to <u>280</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>280</u> ft. depth gage No. <u>0.258</u> | | 10. Screen: Manufacturer's name <u>J+L</u> <input checked="" type="checkbox"/> Type <u>PVC</u> Dia. <u>5</u> Slot/gauze <u>1/16</u> Length <u>60</u> Set between <u>280</u> ft. and <u>340</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/8"</u> | | |
| | | 11. Static water level: <u>143</u> ft. below land surface Date <u>2/9/77</u> mo./day/yr. | | 12. Pumping level below land surfaces: <u>147</u> ft. after <u>2</u> hrs. pumping <u>12</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>25</u> g.p.m. | | |
| | | 13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u> | | 14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u> </u> inches above grade | | |
| 5. Type and color of material | | From | To | 15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft. | | |
| <u>Overburden</u> | | <u>0</u> | <u>143</u> | 16. Nearest source of possible contamination: ft. <u>170</u> Direction <u>SE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| <u>Clay</u> | | <u>143</u> | <u>260</u> | 17. Pump: Manufacturer's name <u>Berkeley</u> Not installed Model number <u>4AM15</u> HP <u>3/4</u> Volts <u>220</u> Length of drop pipe <u>189</u> ft. capacity <u>12</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| <u>Fine Sand + Clay</u> | | <u>260</u> | <u>300</u> | 18. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>T+W Water Well</u> <u>142</u> Business name <u>Box 816 Liberal, Ks.</u> License No. Address <u> </u> Signed <u>C. W. W. W.</u> Date <u>3/6/77</u> Authorized representative | | |
| <u>Medium Sand + Clay</u> | | <u>300</u> | <u>340</u> | 19. Remarks: | | |
| (Use a second sheet if needed) | | | | | | |
| 18. Elevation: | | 20. Water well contractor's certification: | | | | |
| Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>T+W Water Well</u> <u>142</u> Business name <u>Box 816 Liberal, Ks.</u> License No. Address <u> </u> Signed <u>C. W. W. W.</u> Date <u>3/6/77</u> Authorized representative | | | | |

34
37
14
SESENE
1/4 1/4 1/4