

[illegible]

*The Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Essie Blakely  
Stevens County  
12-17-85

Location: NW $\frac{1}{4}$  20-34-37

SE corner of quarter, 200' west  
50' north or 6-3/4 south,  $\frac{1}{2}$  west,  
 $\frac{1}{2}$  north, 200' west, 50' north from  
west side of Hugoton  
Static Water Level - 180

Test #3

0	5	Top soil
5	21	Brown clay
21	39	Fine sand
39	80	Brown sandy clay
80	109	Fine sand - streak of clay (20%)
109	124	Fine to medium sand
124	200	Brown sandy clay
200	290	Fine to medium sand & gravel - streak of clay (10%) (loose) - some brown rock
290	303	Fine to medium sand - streak of clay (10%) (loose)
303	440	Fine to medium sand (loose)
440	510	Fine to medium sand - streaks of clay (10%) (loose)
510	530	Brown yellow red clay & fine sand mixture
530	541	Fine to medium sand & gravel - streaks of clay (10%) (loose)
541	602	Fine to medium sand & gravel (loose)
602	605	Red bed (hard) Used pull down

Total depth 607