

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: Stevens	SW 1/4 SW 1/4 SW 1/4	17	T 34 S	R 38 EW

Distance and direction from nearest town or city street address of well if located within city?

From Peterita: 5S., E. into

2 WATER WELL OWNER: Seaboard Farms	Farm #258 (Smith G/F)
RR#, St. Address, Box #: P.O. Box 1207	Board of Agriculture, Division of Water Resources
City, State, ZIP Code: Guymon, OK 73942	Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL. 420 ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. 187 ft. 2. ft. 3. ft.
	WELL'S STATIC WATER LEVEL 187 ft. below land surface measured on mo/day/yr 8-28-96
	Pump test data: Well water was 273 ft. after 1 hours pumping 250 gpm
	Est. Yield 250 gpm: Well water was ft. after hours pumping gpm
	Bore Hole Diameter 11 in. to 420 ft., and in. to ft.
WELL WATER TO BE USED AS:	
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) Hog farm 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well	
Was a chemical/bacteriological sample submitted to Department? Yes.....No X If yes, mo/day/yr sample was submitted	
Water Well Disinfected? Yes X No	

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
2 PVC	4 ABS	7 Fiberglass	Welded
Blank casing diameter 6 in. to 420 ft. Dia			Threaded
Casing height above land surface 24 in., weight 2.902 lbs./ft. Wall thickness or gauge No. 281 SDR 21			
TYPE OF SCREEN OR PERFORATION MATERIAL:			
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:			
1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes
SCREEN-PERFORATED INTERVALS: From 320 ft. to 420 ft., From ft. to ft., From ft. to ft., From ft. to ft.			
GRAVEL PACK INTERVALS: From 220 ft. to 420 ft., From ft. to ft., From ft. to ft., From ft. to ft.			

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 Bentonite	4 Other Hole Plug
Grout Intervals: From 0 ft. to 16 ft., From ft. to ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:				
1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? How many feet?				

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	Sand Top	264	271	Sand
2	8	Sand	271	280	Sandy Clay
8	10	Clay	280	292	Clay
10	20	Sandy Clay	292	306	Clay / Sandy Clay
20	86	Clay / Sandy Clay	306	320	Red Sandy Clay
86	96	Clay	320	330	Clay
96	105	Sand	330	340	Sand
105	135	Clay	340	352	Sand & Sandy Clay
135	180	Sandy Clay & Clay	352	377	Sand
180	198	Sand W/Clay Streaks	377	389	Sand / Sandy Clay
198	204	Clay	389	407	Clay
204	226	Sand W/Clay Streaks	407	417	Sand
226	231	Clay	417	420	Clay Streaks of Red
231	250	Fine Sand			
250	264	Sandy Clay			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 8-28-96 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. KWWCL - 430 This Water Well Record was completed on (mo/day/yr) 8-28-96 under the business name of Howard Drlg. Box 806, Beaver, Ok 73932 by (signature) <i>Howard Drlg.</i>
