

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: Stevens	NW $\frac{1}{4}$ NE $\frac{1}{4}$ SE $\frac{1}{4}$	9	T 34 S	R 38 E W

Distance and direction from nearest town or city street address of well if located within city?

Liberal; W on 2nd st. rd. to Rd. #7, 4 $\frac{1}{2}$ N & W., into

2 WATER WELL OWNER: Seaboard Farms Co.	Holcomb Farm 258
RR#, St. Address, Box # : P.O. Box 1207	Board of Agriculture, Division of Water Resources
City, State, ZIP Code : Guyton, Ok 73942	Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: 425 ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. 223 ft. 2. ft. 3. ft.
	WELL'S STATIC WATER LEVEL 223 ft. below land surface measured on mo/day/yr 11-25-96
	Pump test data: Well water was 243 ft. after 1 hours pumping 100 gpm
	Est. Yield 100 gpm: Well water was ft. after hours pumping gpm
	Bore Hole Diameter 11 in. to 425 ft., and in. to ft.
WELL WATER TO BE USED AS:	
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 11 Injection well 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well 12 Other (Specify below)	
Was a chemical/bacteriological sample submitted to Department? Yes. No. X If yes, mo/day/yr sample was submitted	
Water Well Disinfected? Yes X No	

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
2 PVC	4 ABS	7 Fiberglass	10 Asbestos-cement
Blank casing diameter 6 in. to 420 ft., Dia in. to ft., Dia in. to ft.			11 Other (specify)
Casing height above land surface 24 in., weight 2.902 lbs./ft. Wall thickness or gauge No. 280 SDR 21			12 None used (open hole)
TYPE OF SCREEN OR PERFORATION MATERIAL:			
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:			
1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes
SCREEN-PERFORATED INTERVALS: From 340 ft. to 420 ft., From ft. to ft.			
GRAVEL PACK INTERVALS: From 150 ft. to 425 ft., From ft. to ft.			

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 Bentonite	4 Other Hole Plug
Grout Intervals: From 0 ft. to 16 ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:		10 Livestock pens		
1 Septic tank	4 Lateral lines	7 Pit privy	11 Fuel storage	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	12 Fertilizer storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	13 Insecticide storage	16 Other (specify below)
Direction from well?		How many feet?		

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	4	Sandy Clay	417	425	Clay
4	60	Clay & Sandy Clay			
60	84	Clay			
84	90	Clay & Sandy Clay			
90	98	Sand			
98	120	Clay & Sandy Clay			
120	138	Sandy Clay			
138	151	Sand			
151	165	Sand & Gravel			
165	186	Sand & Clay Streaks			
186	200	Clay & Sandy Clay			
200	217	Sandy Clay			
217	287	Clay			
287	346	Sandy Clay & Clay Streaks			
346	417	Sand			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 11-23-96 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. KWCL - 430 This Water Well Record was completed on (mo/day/yr) 11-23-96 under the business name of Howard Drlg. Box 806 Beaver, Ok 73932 by (signature) <i>[Signature]</i>
--