


[illegible]

# Henkle

## DRILLING & SUPPLY CO., INC.

3795 W. JONES AVE.  
316/277-2389  
FAX/277-0224

P.O. Box 639  
GARDEN CITY, KANSAS 67846



CUSTOMER'S NAME Scott Kitch DATE June 5, 1990  
STREET ADDRESS 1918 B Street TEST # 1 E. LOG No  
CITY & STATE Garden City, Ks. 67846 DRILLER Shelden  
COUNTY Stevens QUARTER NW SECTION 13 TOWNSHIP 34 RANGE 39  
LOCATION 80' Southwest of house

%	FOOTAGE			DESCRIPTION OF STRATA	STATIC WATER LEVEL: <u>Approx. 180'</u> Proposed Well Depth: <u>370'</u>
	From	Pay	To		
	0		2	Top soil	
	2		43	Brown sandy clay	
	43		50	Caliche & lime rock	
	50		97	Brown clay	
	97		136	Red clay & some lime rock ledges	
	136		146	Sand fine to medium	
	146		157	Brown clay	
	157		168	Sand fine to medium few coarse	
	168		214	Brown silty clay & lime rock streaks	
55	214	12	226	Sand fine to medium coarse with some small black rock	
50	226	24	250	Sand fine to medium coarse with some small gravel & some silty clay strips. Drill loose in places	
	250		318	Brown silty clay	
55	318	15	333	Sand fine to medium coarse	
50	333	37	370	Sand fine to medium coarse with some silty clay streaks. Drilled loose in places	
	370		411	Brown clay with some red clay streaks	
45	411	8	419	Sand fine to some medium	
40	419	20	439	Sand fine to medium with lots silty clay streaks	
60	439	11	450	Sand fine to medium coarse with some small rock	
	450		464	Brown clay	
	464		470	Red bed ledge & red bed	
	470		487	Gray & yellow soap stone with some red bed streaks	
	487		502	Red bed	
				TD = 370'	
				Perf	Plain
	370	to	320	50'	
	320	to	0		320'
				Total 50'	320'
				2½ - 50 lb. Bags Hi-Tek	
				6 - 50 lb. Bags Hole Plug	
				2 - 5 gallon buckets ¼" Pellets	
				2 - 6" PVC Caps	

SERVING THE GREAT SOUTHWEST *with* WATER, WHERE AND WHEN YOU WANT IT.