

1. Location of well:	County Morton	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 33	Township number T 34 S R 41 E/W
2. Distance and direction from nearest town or city: 2 South West of Wilburton, Kan Street address of well location if in city:			3. Owner of well: Wesley Bressler R.R. or street: Route 1 Box 64 City, state, zip code: ELKHART, KAN	
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W [Diagram: A 3x3 grid with dashed lines. The center square contains an 'X'. Labels NW, NE, SW, SE are in the corners. An arrow points right labeled 'E' and another down labeled 'S'. Below the grid is a scale bar for 1 mile.] S 1 Mile E</div>			Sketch map:	
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 6/16/76 Well depth 265 ft.	
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>	
			9. Casing: Material Steel Height: Above or below surface 10 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.5 lbs./ft. Dia. 16 in. to 265 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250	
			10. Screens: Manufacturer's name L.B. Foster Type Steel Dia. 16" Slot/gauze 1/8 Length 3 Set between 180 ft. and 220 ft. 240 ft. and 265 ft. Gravel pack? yes Size range of material 1/8 - 1/4	
			11. Static water level: _____ mo./day/yr. 155 ft. below land surface Date 6/18/76	
			12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
			14. Well head completion: NA Pitless adapter _____ Inches above grade	
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other _____	
(Use a second sheet if needed)				
18. Elevation:	19. Remarks: 10A. Johnson Err, .1000 slot Steel 16" 220-240' 16A Cropland		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KTM DRILLING, INC. 225 Business name Box 1905, Guymon, OKIA. Address Fredy Baker Signed _____ Date 7/24 Authorized representative	

$$\begin{array}{r} 34 \\ - 41 \\ \hline 33 \\ \hline \end{array}$$