WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: COUNTY: NORTON	Fraction SW 1/4 SW 1/4 SW 1/4	Section Number 33	Township Number T 34 S	Range Number R 42 W

Distance and direction from nearest town or city street address of well if located within city?
FROM ELKHART, KS. - 2 MILES NORTH ON HIGHWAY 27

2 WATER WELL OWNER: U.S. FOREST SERVICE (at Work Center at Cimmaron)
RR#, St. Address, Box # : BOX 300
City, State, ZIP code : ELKHART, KS 67950-

Board of Agriculture, Division of Water Resources
Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:



4 DEPTH OF COMPLETED WELL 203 ELEVATION: 0
Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.

WELL'S STATIC WATER LEVEL 113 ft. below land surface measured on mo/day/yr 06/21/96
Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm

Estimated Yield 12 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm

Bore Hole Diameter 10 in. to 203 ft., and in. to 0 ft.

WELL WATER TO BE USED AS: DOMESTIC

Was a chemical/bacteriological sample submitted to department? No ;
If yes, mo/day/yr sample was submitted Water well disinfected? Yes

5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED
Blank casing diameter 6 in. to 203 ft., Dia in. to 0 ft., Dia in. to 0 ft.
Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC
SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 120 ft. to 140 ft., From 0 ft. to 0 ft.
From 180 ft. to 200 ft., From 0 ft. to 0 ft.
GRAVEL PACK INTERVALS: From 30 ft. to 203 ft., From 0 ft. to 0 ft.
From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE
Grout Intervals: From 0 ft. to 30 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.
What is the nearest source of possible contamination: ABANDONED WELL
Direction from well? EAST How many feet? 20

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	TOPSOIL FINE SAND			
20	40	FINE - MED SAND CLAY LAYERS			
40	60	CLAY FINE - MED SAND SMALL GRAVEL			
60	80	FINE SAND COARSE SAND SMALL GRAVEL			
80	100	CLAY FINE SAND IN LAYERS			
100	140	FINE SAND THIN ROCK LAYER			
140	160	FINE SAND RED CLAY			
160	180	RED CLAY SANDSTONE			
180	210	SANDSTONE RED CLAY			
210	240	RED BED			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 06/21/96 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This water Well Record was completed on (mo/day/yr) 07/01/96 under the business name of JOE'S WELL SERVICE, INC. by (signature) Judith Crick