

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Meade		Fraction $\frac{1}{4}$ SW $\frac{1}{4}$ SW $\frac{1}{4}$	Section number 7	Township number 35	Range number 28	E/W E/W
2. Distance and direction from nearest town or city: $\frac{1}{2}$ S of Port S Meade Lake, 4E, 3S, $\frac{1}{2}$W to loc.			3. Owner of well: Triad Drilling Co. R.R. or street: 1100 Bitting Bldg. City, state, zip code: Wichita, Kansas 67202			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 2-12-		
				Well depth 240 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		2	40	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 155 ft. depth Wall Thickness: inches or Dia. 5 in. to 240 ft. depth gage No. 265		
Sandy clay		40	60	10. Screen: Manufacturer's name sawed Type PVC Dia. 8" Slot/gauze 80 Length 80 Set between 155 ft. and 235 ft. Gravel pack? yes Size range of material 1/8 to		
Clay		60	90	11. Static water level: 50 ft. below land surface Date 2-18-77		
Medium to large sand		90	160	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 60 g.p.m.		
Clay and medium to large sand		160	180	13. Water sample submitted: 2-12-77 <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Medium to large sand		180	240	14. Well head completion: 28 inches above grade <input type="checkbox"/> Pitless adapter		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: 100 ft. Direction NE Type oilwell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: _____		19. Remarks: Too much water		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name _____ License No. _____ Address Box 275, Liberal, Ks. Signed Edward E. Means Date 2-18- Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5