

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Seward	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 8	Township number T 35 S R 31 E/W	Range number
2. Distance and direction from nearest town or city: 9E. 2S. 1 1/2 E 1/2 N. of Liberal, KS.			3. Owner of well: Dale Newman R.R. or street: RR City, state, zip code: Liberal, Kansas 67901			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date _____ Well depth 300 ft. 2/25/77		
		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded GI Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 220 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.258		
5. Type and color of material				From	To	10. Screen: Manufacturer's name _____ Type PVC Dia. 5" Slot/gauze 1/16 Length 80 Set between 220 ft. and 300 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8"
Overburden				0	172	11. Static water level: _____ mo./day/yr. 172 ft. below land surface Date 2/25/77
Clay				172	190	12. Pumping level below land surfaces: 180 ft. after 2 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.
Fine Sand + Clay				190	238	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Medium Sand + Clay				238	300	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
						16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: _____ Not installed Manufacturer's name Berkeley Model number 4BL27 HP 1 1/2 Volts 220 Length of drop pipe 252 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Water Well 142 Business name _____ License No. _____ Address Box 816 Liberal, KS Signed [Signature] Date 4/21/77 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 35 S R 31 E
 Sec 8
 SWSUSE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5