PERMIT #T78-137

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215 Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CWW TUY #	14032	Smyser #1-/							
	County	Fraction		Section number		Township number	Range number		
1. Location of well:	Seward	x 4 x 4 C−S			7	т 35 S s	R 32W	E/W	
					ner of well: Service Drilling Company				
1 Street address of welt location if in city:						: 910 orger, Texas 790	07		
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 9 in	. Completion date	-20	
N						Well depth 280 ft.			
LIBERAL						7 Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary			
س ا ا ا ا ا						8. Use: Domestic Public supply X Industry			
						Irrigation Air conditioning Stock			
						Lawn XO il field water Other			
() () () () () () () () () ()						9. Casing: Material	_ Height: Above or be	elow	
1 1 3/4m EASE						9. Casing: Material Height: Above or below Threaded Welded Surface 28 in. RMP PVC X Weight 2.78 lbs./ft.			
1 Mile ————————————————————————————————————						Dia. 5 in. to 215t. dep	th Wall Thickness: inc	hes or	
5. Type and color of material				From	То	Dia. 5 in. to 280 ft. depth gage No265			
05						10. Screen: Manufacturer's n Sawed perfor			
Surface				0	2	Туре РVС	_ Dia5		
Sandy clay				2	140	Slot/gauze	Length 80'		
Fine sand & medium to large sand 70-30				1 4 0	190	ft. a	ind255		
						11. Static water level:	mo.	/day/yr.	
Fine sand & sandy clay 60-40				190	250	ft. below land sur	face Date	D <u>= 78</u>	
Blue sandy clay				250	260	12. Pumping level below land			
Blue clay				260	280	ft. after hrs. pumping g.p.m ft. after hrs. pumping g.p.m.			
				200	200	Estimated maximum yield 40 g.p.m.			
						13. Water sample submitted:		/day/yr.	
							Date		
						14. Well head completion: Pitless adapter Inches above grade			
						15. Well grouted? YES		\ .	
						With: X Neat cement Bentonite Concrete Depth: From 0 ft. to 10 ft.			
						16. Nearest source of possible		ν	
						ft100 DirectionNE Typeilwell1 Well disinfected upon completion?X Yes No			
						17. Pump:	X Not installed		
						Manufacturer's name		\ \ \ \ \	
						Model number		g.p.m. (§	
						Type:	copacity	a.b	
						Submersible	Turbine		
(Use a second sheet if needed)						Jet Centrifugal	Reciprod Other	sating Sec	
18. Elevation:	19. Remarks:	."				20. Water well contractor's o			
						This well was drilled under my is true to the best of my know		report	
Topography:		4				Carlile water W	•	<u>. 118 ≥ </u>	
Hill Stone						Business name		nse No.	
X Upland						Address 2000 P	Mean	7-27-78	
Valley	·					Signed Authorized repr	esentative Date	<u></u> <u></u>	