

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CWW Inv. #13751

Light #1

1. Location of well:	County Seward	Fraction 1/4 SW 1/4 SW 1/4	Section number 10	Township number T 35S S R 32W E/W	Range number
2. Distance and direction from nearest town or city: From South Port of Entry go 6 mi. East - north to location.			3. Owner of well: Sage Drilling Company R.R. or street: 500 Bitting Building City, state, zip code: Wichita, Kansas 67202		
4. Locate with "X" in section below:		Sketch map:			
		6. Bore hole dia. <u>9</u> in. Completion date <u>8-19</u> Well depth <u>280</u> ft. 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface <u>28</u> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight <u>2.78</u> lbs./ft. Dia. <u>5</u> in. to <u>170</u> ft. depth; Wall Thickness: inches or Dia. <u>5</u> in. to <u>280</u> ft. depth; gage No. <u>265</u> 10. Screen: Manufacturer's name _____ Sawed perf. Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze _____ Length <u>100'</u> Set between <u>170</u> ft. and <u>270</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>1/8-3/16</u> 11. Static water level: _____ mo./day/yr. <u>180</u> ft. below land surface Date <u>8/19/77</u> 12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>65</u> g.p.m. 13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ 14. Well head completion: <input type="checkbox"/> Pitless adapter _____ 28 Inches above grade 15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft. 16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>NE</u> Type <u>oilwell</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name _____ License No. _____ Address <u>Box 275, Liberal, KS</u> Signed <u>Edward E. Mearns</u> Date <u>9-6-</u> Authorized representative			
Surface		0	2		
Fine sand		2	20		
Clay		20	40		
Sandy clay		40	60		
Clay		60	80		
Medium to large sand & sandy clay 40-60		80	100		
Medium to large sand & sandy clay 90-10		100	160		
Medium to large sand		160	250		
Medium to large sand & caliche 70-30		250	265		
Medium to large sand		265	280		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		(Use a second sheet if needed)			

T 35S S R 32W E
 Sec 10 SW 35
 1/4 1/4 N 1/4