

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Seward	Township name	Fraction SE SE	Section number 3	Town number 35S	Range number 33W
Distance and direction from nearest town or city: 2 miles east of Liberal				3 Owner of well: Unit Drilling Company		
Street address of well location if in city:				Address: 1101 Pet. Club Bldg. Tulsa, Oklahoma 74119		
Locate with "X" in section below:		Sketch map:		4 Well depth: <u>300</u> ft. Date of completion <u>8-11-75</u> Well diameter <u>9</u> in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> Oil Rig		
2		Type and color of material		From To		7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>28</u> in. Diam. <u>5</u> in. Weight <u>2.78</u> lbs./ft. <u>5</u> in. to <u>260</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>5</u> in. to <u>300</u> ft. depth
						8 Screen: Manufacturer <u>sawed perf.</u> Type <u>PVC</u> Dia. <u>5</u> Slot/gauze <u>.030</u> Length <u>30</u> Set between <u>260</u> ft. and <u>290</u> ft. Fittings: <u>1/8 to 3/16</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u> </u>
Surface				0 2		9 Static water level: <u>127</u> ft. below land surface Date <u>8-11-75</u>
Fine sand				2 12		10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>60</u> g.p.m.
Clay				12 57		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____
Sandy clay				57 94		12 Well head completion: <input type="checkbox"/> Pitless adapter <u>20</u> inches above grade
Fine Sand				94 100		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.
Clay				100 112		14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>NE</u> Type <u>oil well</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Caliche				112 158		15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Clay				158 180		16 Remarks: elevation
Sandy clay				180 260		Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley
Clay and fine sand 10-90				260 300		
(use a second sheet if needed)						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name License No. Address <u>Box 275, Liberal, Ks.</u> Signed <u>Edward E. Means</u> Date <u>8-22-75</u> Authorized representative

35 33W 3 SESE