

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment (Water well Contractors)
Topeka, Kansas 66620

Invoice No. 12271

1. Location of well: County <u>Seward</u>		Fraction <u>1/4 NE 1/4 NE 1/4</u>		Section number <u>13</u>		Township number <u>T 35 S R 33 E/W</u>		Range number	
2. Distance and direction from nearest town or city: <u>1 South and 2 3/4 east of Liberal</u> Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:		Gary Warden RFD #1 Liberal, Kansas 67901			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: <i>Liberal</i> <i>11711</i> <i>South</i> <i>334F</i> <i>Section</i>		6. Bore hole dia. <u>12 1/2</u> in. Completion date <u>4-26-76</u> Well depth <u>252</u> ft.			
5. Type and color of material				From		To		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				Surface		0		2	
Fine to medium sand & sandy clay 60-40				2		80		9. Casing: Material _____ Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>28</u> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight <u>2.78</u> lbs./ft. Dia. <u>6</u> in. to <u>165</u> ft. depth Wall Thickness: inches or Dia. <u>6</u> in. to <u>252</u> ft. depth gage No. <u>265</u>	
Fine to medium sand and sandy clay 40-60				80		120		10. Screen: Manufacturer's name _____ XXXX <u>Wesco</u> Type <u>Steel</u> PVC Dia. <u>6"</u> Slot/gauze <u>.030</u> Length <u>20</u> Set between <u>165</u> ft. and <u>175</u> ft. <u>222</u> ft. and <u>232</u> ft.	
Medium to large sand & sandy clay 70-30				120		140		11. Static water level: _____ mg./day/yr. <u>140</u> ft. below land surface Date <u>4-26-76</u>	
Medium to large sand & sandy clay 80-20				140		220		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Fine to medium sand & Rock caliche 50-50				220		230		13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Fine to medium sand and sandy clay 80-20				230		240		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade	
Fine to medium sand and blue sandy clay 20-80				240		260		15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
								16. Nearest source of possible contamination: <u>None</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: _____ Not installed Manufacturer's name <u>Sta-rite</u> Model number <u>40PLJ2</u> HP <u>5</u> Volts <u>230</u> Length of drop pipe <u>210</u> ft. capacity <u>50</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
								(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Carlile Water Well</u> <u>118</u> Business name _____ License No. _____ Address <u>Box 275, Liberal, Ks.</u> Signed <u>Edward E. Mann</u> Date <u>5-12</u> Authorized representative	

T 35
 R 33
 E/W
 13
 1/4 NE 1/4 NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5