

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

McDonald #1 Inv. # 11157

1 Location of well:	County Seward	Township name	Fraction SE SW	Section number 18	Town number 35S	Range number 33W
Distance and direction from nearest town or city: 1 mile east of Liberal 1 1/2 south and 1/2 east. Street address of well location if in city:				3 Owner of well: Unit Drilling Company Rig #1 Address: 1101 Petroleum Club Bldg. Tulsa, Oklahoma 74119		
Locate with "X" in section below: N		Sketch map:		4 Well depth: 220 ft. Date of completion 7-4-75 Well diameter 9 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> Oil Rig		
2		Type and color of material		From	To	7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. Diam. Weight 2.78 lbs./ft. 5 in. to 180 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 2 in. to 220 ft. depth
		Surface		0	2	8 Screen: Manufacturer sawed perforations Type Plastic Dia. 5" Slot/gauze .030 Length 30 Set between 180 ft. and 210 ft. Fittings: 1/8 - 3/16 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
		Sandy clay		2	25	9 Static water level: 95 ft. below land surface Date 7-4-75
		Med. to Large Sand		25	90	10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 45 g.p.m.
		Sandy clay		90	110	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
		Sandy clay		110	170	12 Well head completion: <input type="checkbox"/> Pitless adapter 20 inches above grade
		Clay & Med. to large sand 20-90		170	120	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
						14 Nearest source of possible contamination: ft. 100 Direction NE Type Oil Well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
		(use a second sheet if needed)				16 Remarks: elevation
						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name License No. Address Box 275, Liberal, Kansas Signed [Signature] Date 7-11-75 Authorized representative

35 33W 18 SE SW