

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

35 S 34 W Sec SE 12
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Seward	Township name	Fraction SE-SE	Section number 12	Town number 35S	Range number 34W																																
Distance and direction from nearest town or city: 2 miles southeast of Liberal			3 Owner of well: George Tedford Address: 202 N. Princeton Liberal, Kansas 67901																																			
Locate with "X" in section below:		Sketch map:		4 Well depth: 180 ft. Date of completion 10-12-74 Well diameter 9 in.																																		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																																		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Stock																																		
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="2">2 Type and color of material</th> <th>From</th> <th>To</th> </tr> <tr> <td>Surface</td> <td></td> <td>0</td> <td>2</td> </tr> <tr> <td>Brown clay</td> <td></td> <td>2</td> <td>20</td> </tr> <tr> <td>Sandy clay</td> <td></td> <td>20</td> <td>80</td> </tr> <tr> <td>Clay</td> <td></td> <td>80</td> <td>100</td> </tr> <tr> <td>Sandy clay</td> <td></td> <td>100</td> <td>140</td> </tr> <tr> <td>Fine to medium sand</td> <td></td> <td>140</td> <td>160</td> </tr> <tr> <td>Sandy clay</td> <td></td> <td>160</td> <td>180</td> </tr> </table>		2 Type and color of material		From	To	Surface		0	2	Brown clay		2	20	Sandy clay		20	80	Clay		80	100	Sandy clay		100	140	Fine to medium sand		140	160	Sandy clay		160	180			7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 1/2 in. to 140 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 1/2 in. to 140 ft. depth		
		2 Type and color of material		From	To																																	
		Surface		0	2																																	
		Brown clay		2	20																																	
		Sandy clay		20	80																																	
		Clay		80	100																																	
		Sandy clay		100	140																																	
		Fine to medium sand		140	160																																	
Sandy clay		160	180																																			
8 Screen: Manufacturer Wesco Type sawed 1030 Dia. 5 1/2" Slot/gauze 0.30 Length 40 Set between 140 ft. and 180 ft. Fittings: 1/8-3/16" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ---																																						
9 Static water level: 105 ft. below land surface Date 11-12-74																																						
10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 40 g.p.m.																																						
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																																						
12 Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade																																						
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.																																						
14 Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																						
16 Remarks: elevation				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name License No. Address Box 275, Liberal, Ks. Signed Edward E. Moore date 10-20-74 Authorized representative																																		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																																						