

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Seward	Fraction SE/4 SE 1/4 SE 1/4	Section number 13	Township number T 35 S R	Range number 34 E (W)
2. Distance and direction from nearest town or city: 2 miles west liberal-2 miles south Street address of well location if in city:				3. Owner of well: Mrs. G.C. Apsley R.R. or street: 316 N. Prospect City, state, zip code: Liberal, Kansas 67901		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date 6/7/81 Well depth 260 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. RMP 5 PVC Glued Weight _____ lbs./ft. Dia. 5 in. to 180 ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. 0258		
Overburden		0	95	10. Screen: Manufacturer's name Lone Star Type PVC Dia. 5" Slot/gauze 1/16 Length 80 Set between 180 ft. and 260 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/8		
Fine Sand & Clay		95	120	11. Static water level: _____ mo./day/yr. 95 ft. below land surface Date 6/7/81		
Medium sand & clay		120	140	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.		
Clay		140	160	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay & rock		160	180	14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 14 inches above grade		
Medium sand & clay		180	240	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
Fine sand & blue clay		240	260	16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Goulds Model number KTMB50 HP 5 Volts 230 Length of drop pipe 210 ft. capacity 60 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T & W Water Well Serv. 142 Business name _____ License No. _____ Address Box 816 Liberal Ks. 67901 Signed <i>[Signature]</i> Date 6/15/81 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		16. well drilled in pasture/field 17. Pump used in well 10 days then pulled well was capped.				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5