USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Stevens		NE,NE,NW	2	35S	35W

Distance and direction from nearest town or city: 10 Miles west of Liberal, Kansas

Street address of well location if in city:

3 Owner of well: Alene Mahoney
Address: 216 40th Sacramento, California

Locate with "X" in section below:



Sketch map: Well drilled near TH 3-75 which is 520' south of NE corner of NW¼, Sec. 2, T35S, R35W, Stevens County, Kansas.

4 Well depth: 422 ft. Date of completion 11-19-75
Well diameter 28 in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐ ____

7 Casing: Material Stl Height: above/below
Threaded ☐ Welded ☒ Surface 12 in.
Diam. Weight 39 lbs./ft.
16 in. to 199 ft. depth Drive shoe? ☐ Yes ☒ No
___ in. to ___ ft. depth

2 Type and color of material	From	To
Top soil	0	3
Green clay	3	20
Tan clay fine sand lenses	20	90
Fine to coarse sand	90	136
Tan clay with caliche	136	190
Fine to coarse sand clay lenses	190	240
Tan and white clay sand lenses	240	270
Fine to coarse sand	270	338
Fine to coarse sand clay lensesq	338	390
Fine to medium sand	390	422
Mixed clays	422	500
(use a second sheet if needed)		

8 Screen:
Manufacturer Foster & Brown
Type Mill slot & louver Dia. 16"
Slot/gauze 1/8" Length 223
Set between 199 ft. and 422 ft.
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material 1.1 mm to 5.5 mm

9 Static water level:
134 ft. below land surface Date 10-7-1975

10 Pumping level below land surfaces:
200 ft. after ½ hrs. pumping 1016 g.p.m.
212 ft. after 1 hrs. pumping 2061 g.p.m.
Estimated maximum yield 2,000 g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date ____

12 Well head completion:
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☐ Neat cement ☒ Bentonite ☐ ____
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination: unk
ft. ____ Direction ____ Type ____
Well disinfected upon completion? ☐ Yes ☐ No

15 Pump: ☐ Not installed
Manufacturer's name Layne & Bowler
Model number 12 HP 145 Volts ___
Length of drop pipe 260 ft. capacity 1200 g.m.p.
Type:
☐ Submersible ☒ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Layne-Western Co., Inc. 150
Business name License No.
Address Garden City
Signed [signature] Date ____
Authorized representative 20 Nov 75

35 35W 2 NE NE NW

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5