


1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: STEVENS	SW 1/4 SW 1/4 SW 1/4	5	T 35 S	R 37 EW

Distance and direction from nearest town or city street address of well if located within city?

2 WATER WELL OWNER: BEREDCO	ROY DURE #1
RR#, St. Address, Box # : 401 E. DOUGLAS, STE 402	Board of Agriculture, Division of Water Resources
City, State, ZIP Code : WICHITA, KS 67202	Application Number: 940440

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: 400 ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. 150 ft. 2. ft. 3. ft.
	WELL'S STATIC WATER LEVEL 150 ft. below land surface measured on mo/day/yr 10-21-94
	Pump test data: Well water was 170 ft. after 1 hours pumping 95 gpm
	Est. Yield 95 gpm: Well water was ft. after hours pumping gpm
	Bore Hole Diameter 9 1/2 in. to 400 ft. and in. to ft.
	WELL WATER TO BE USED AS:
	5 Public water supply 8 Air conditioning 11 Injection well
	1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
	2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
	Was a chemical/bacteriological sample submitted to Department? Yes No X; If yes, mo/day/yr sample was submitted
	Water Well Disinfected? Yes X No

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
2 PVC	4 ABS	7 Fiberglass	10 Asbestos-cement
Blank casing diameter 5 in. to 400 ft. Dia			11 Other (specify)
Casing height above land surface 24 in. weight 2.902 lbs./ft. Wall thickness or gauge No. 265 SDR 21			12 None used (open hole)
TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC		
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	3 Mill slot	9 Drilled holes	
2 Louvered shutter	4 Key punched	10 Other (specify)	
SCREEN-PERFORATED INTERVALS:	From 340 ft. to 400 ft.		
GRAVEL PACK INTERVALS:	From 320 ft. to 400 ft.		

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 Bentonite	4 Other	HOLE PLUG
Grout Intervals: From 1 ft. to 20 ft.					
What is the nearest source of possible contamination:	1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
	2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
	3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well?				13 Insecticide storage	
				How many feet?	

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	SANDY CLAY	360	400	SAND & GRAVEL
2	16	CLAY			
16	86	CALICHE CLAY			
86	109	SANDY CLAY			
109	126	CALICHE CLAY			
126	176	SANDY CLAY			
176	186	FINE SAND			
186	190	CLAY			
190	206	SANDY CLAY			
206	218	COARSE SAND			
218	222	CLAY			
222	269	COARSE SAND			
269	273	CLAY			
273	284	SAND & SMALL GRAVEL			
284	360	COARSE SAND			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 10-21-94 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. KWWCL-430 This Water Well Record was completed on (mo/day/yr) 10-21-94 under the business name of HOWARD DRUG CO. BOX 806 BEAVER, OK 73932 by (signature) Howard
---