

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: STEVENS	NE 1/4 NE 1/4 NW 1/4	7	T 35 S	R 38W E/W

Distance and direction from nearest town or city street address of well if located within city?

FROM LIBERAL, WEST ON 2nd ST. TO 3rd STOP SIGN, 3/4 SW, TO C.G. 1/2 WEST, 1/8 & 1/2 SOUTH TO WELL.

2 WATER WELL OWNER: SEABOARD FARMS CO.	"KRAMER NORTH WELL"
RR#, St. Address, Box # : P.O. BOX 1207	Board of Agriculture, Division of Water Resources
City, State, ZIP Code : GUYMON, OK 73942	Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: 400 ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. 190 ft. 2. ft. 3. ft.
	WELL'S STATIC WATER LEVEL 190 ft. below land surface measured on mo/day/yr 04-24-96
	Pump test data: Well water was 210 ft. after 1 hours pumping 100 gpm
	Est. Yield 100 gpm: Well water was ft. after hours pumping gpm
	Bore Hole Diameter 11 in. to 400 ft., and in. to ft.
WELL WATER TO BE USED AS:	
5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well <i>Hog farm</i>	
Was a chemical/bacteriological sample submitted to Department? Yes.....No X; If yes, mo/day/yr sample was submitted	
Water Well Disinfected? Yes X No	

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
2 PVC	4 ABS	7 Fiberglass	Welded
Blank casing diameter 6 in. to 400 ft., Dia			Threaded
Casing height above land surface 24 in., weight 2.902 lbs./ft. Wall thickness or gauge No. .280 SDR 21			
TYPE OF SCREEN OR PERFORATION MATERIAL:			
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:			
1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut
2 Louvered shutter	4 Key punched	6 Wire wrapped	11 None (open hole)
SCREEN-PERFORATED INTERVALS:			
From 320 ft. to 400 ft., From ft. to ft.			
GRAVEL PACK INTERVALS:			
From 220 ft. to 400 ft., From ft. to ft.			

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 Bentonite	4 Other HOLE PLUG
Grout Intervals: From 0 ft. to 16 ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:				
1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? How many feet?				

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	CLAY	272	280	SAND & SANDY CLAY
2	27	CLAY & SANDY CLAY	280	284	CLAY
27	35	CLAY	284	296	SANDY CLAY
35	50	SANDY CLAY	296	304	CLAY
50	97	CLAY	304	326	SAND
97	142	CLAY & SANDY CLAY	326	345	COARSE SAND & SANDY CLAY
142	158	CLAY	345	365	COARSE SAND
158	179	SANDY CLAY	365	378	COARSE SAND W/RED CLAY STREAKS
179	184	CLAY	378	387	COARSE SAND
184	200	SANDY CLAY	387	400	RED
200	226	CLAY			
226	245	CLAY & SANDY CLAY			
245	255	CLAY			
255	270	SAND & SANDY CLAY			
270	272	CLAY			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 04-24-96 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. KWCL-430 This Water Well Record was completed on (mo/day/yr) 04-24-96 under the business name of HOWARD DRUG CO. BOX 806 BEAVER, OK 73932 by (signature) <i>Howard Drug Co.</i>
--

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.