

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction Center of 1/4 1/4 SW 1/4	Section number 12	Township number T 35 S R 38 E	Range number 38
2. Distance and direction from nearest town or city: 2 miles South 2 miles West 2 miles South 3/4 miles West 1/2 mile North of Hugoton			3. Owner of well: Zenith Drilling Corporation R.R. or street: Suite 600 200 West DOUGLAS City, state, zip code: Wichita, Kansas 67202			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div>			Sketch map: <div style="text-align: center;">NW NE SW SE</div>			
5. Type and color of material			From	To	6. Bore hole dia. _____ in. Completion date Well depth 240 ft. 10/25/78	
Over burden			0	115'	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
fine sand + clay			115'	175'	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
fine to med. sand & clay streaks			175'	240'	9. Casing: Material PVC Height: Above or below Threaded _____ Welded glue Surface 34 in. RMP _____ PVC 7 Weight 200 lbs./ft. Dia. 5 in. to 160 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.258	
					10. Screen: Manufacturer's name Peerless Plastic Type PVC Dia. 5" Slot/gauze 1/16 Length 80' Set between 160 ft. and 240 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/8	
					11. Static water level: _____ mo./day/yr. 115 ft. below land surface Date 10/25/78	
					12. Pumping level below land surfaces: 140 ft. after 1 hrs. pumping 80 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: Manufacturer's name Pioneer Not installed Model number _____ HP 1/2 Volts 230 Length of drop pipe 210 ft. capacity 80 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. TJW Water Well Service Inc. 1427 Business name Box 816 Liberal KS 67901 License No. _____ Address _____ Signed Ed. Hoge Date 12/14/78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

35 380 12
CSW