

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

• P.O. Box A •

GARDEN CITY, KANSAS 67846

David Light
Morton County
8/29/01

Location: NW¼ 8-35-39 - From Rolla - 6 miles south, 2 miles east,
1½ miles south & 50 ft. east to old well
(Offset 250 ft. north)

Static Water Level - 240 ft.

Test #1

0' to 2' - Top soil
2' to 6' - Brown clay
6' to 27' - Fine sand
27' to 53' - Brown clay
53' to 72' - Fine sand - clay streak
72' to 143' - Brown sandy clay
143' to 158' - Brown clay
158' to 190' - Brown sandy clay
190' to 201' - Fine sand - 10% clay
201' to 206' - Fine fine sand
206' to 215' - Brown sandy clay
215' to 227' - Fine sand
227' to 274' - Brown clay
274' to 281' - Fine sand
281' to 326' - Brown clay
326' to 333' - Fine fine sand
333' to 350' - Brown clay
350' to 404' - Brown sandy clay
404' to 410' - Fine sand
410' to 442' - Fine to medium sand - tight
442' to 458' - Brown sandy clay
458' to 471' - Brown sandy clay - small gravel brown rock streak
471' to 485' - Brown sandy clay - 35% gravel brown rock - hard pull down 300
485' to 493' - Brown sandy clay
493' to 500' - Red bed - hard pull down 300