


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Morton	Township name S.E.,S.E.,S.E.	Fraction 3	Section number T35S	Town number R41W	Range number
Distance and direction from nearest town or city: 3 miles south of Wilburton, Kansas Street address of well location if in city:				3 Owner of well: James Curtis Address: Box 218 Elkhart, Kans. 67950			
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: 284 ft. Date of completion 5-12-75 Well diameter 9 in.			
2		Type and color of material		From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		Overburden		0	221	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
		Medium Sand		221	242	7 Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 36 in. Diam. 5 in. to 124 ft. depth Weight 320 lbs. in. to ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
		Course Sand & Small Gravel		240	281	8 Screen: Manufacturer Jess & Lowell Type RMP Dia. 5 ft. Set/gauze 1/16 Length 60 Set between 224 ft. and 284 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8	
		Red Bed		281	284	9 Static water level: 221 ft. below land surface Date 5-12-75	
						10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.	
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
						12 Well head completion: 36 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 3 ft. to 13 ft.	
						14 Nearest source of possible contamination: None ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation		(use a second sheet if needed)				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T & W Water Well Ser. 142 Business name License No. Address C.D. Wagenseller Box 816 Signed C.D. Wagenseller Date 5-12-75 Authorized representative	