


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:		County <u>Morton</u>	Township name	Fraction <u>SE</u> <u>SESE</u>	Section number <u>16</u>	Town number <u>T 35 S</u>	Range number <u>R 42 W</u>
Distance and direction from nearest town or city: <u>1/2 mi. NE of Elkhart, Kansas</u>					3 Owner of well: <u>Claude Benedict</u> Address: <u>Elkhart, Kansas</u>		
Locate with "X" in section below: 					Sketch map:		
2					4 Well depth: <u>280</u> ft. Date of completion <u>9/25/75</u> Well diameter <u>9</u> in.		
Type and color of material					5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
From To					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Overburden					7 Casing: Material <u>RMP</u> Height: <u>above/below</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>14</u> in. Diam. <u>5</u> in. to <u>220</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>5</u> in. to <u>220</u> ft. depth		
Clay					8 Screen: Manufacturer <u>J+L</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>60</u> Set between <u>220</u> ft. and <u>280</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/8</u>		
Medium Sand and Clay					9 Static water level: <u>185</u> ft. below land surface Date <u>9/25/75</u>		
Red Clay and Sand Stone					10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>60</u> g.p.m.		
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
					12 Well head completion: <u>14"</u> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>3</u> ft. to <u>13</u> ft.		
					14 Nearest source of possible contamination: ft. <u>300</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)							
16 Remarks: elevation					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>T.W. Water Well</u> <u>142</u> Business name License No. Address <u>PO Box 816 Liberal KS</u> Signed <u>C.D. Dugan</u> Date <u>9/25/75</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					Well Completed by: <u>H.P. Steele Water Well Service</u> <u>Elkhart, KS.</u>		

35 42 W 16 SESESE