

WATER WELL RECORD Form WWC-5

Original Record Correction Change in Well Use

Division of Water Resources App. No.

Corrected RAMUS 000433

Well ID

1 LOCATION OF WATER WELL:

County: Morton

Fraction SW 1/4 NE 1/4 NW 1/4 NW 1/4

Section Number 16

Township Number T 35 S

Range Number R 42 E W

2 WELL OWNER: Last Name:


Business: KDHE
Address: 1000 SW Jackson St
City: Topeka

First:

State: KS ZIP: 66612

Street or Rural Address where well is located (if unknown, distance and direction from nearest town or intersection): If at owner's address, check here:
In Elkburg, KS

3 LOCATE WELL WITH 'X' IN SECTION BOX:



4 DEPTH OF COMPLETED WELL: 238 ft.
Depth(s) Groundwater Encountered: 1) 198 ft.
WELL'S STATIC WATER LEVEL: 203.83 ft.
Bore Hole Diameter: 8 in. to 238 ft. and 238 in. to ft.

5 Latitude: 37.00890 (decimal degrees)
Longitude: 101.89587 (decimal degrees)
Datum: WGS 84 NAD 83 NAD 27
Source for Latitude/Longitude: GPS (unit make/model) Land Survey Topographic Map Online Mapper

6 Elevation: 3605 ft. Ground Level TOC
Source: Land Survey GPS Topographic Map Other KOLAR

7 WELL WATER TO BE USED AS:

- 1. Domestic Household Lawn & Garden Livestock
2. Irrigation
3. Feedlot
4. Industrial
5. Public Water Supply: well ID
6. Dewatering: how many wells?
7. Aquifer Recharge: well ID
8. Monitoring: well ID 0564353
9. Environmental Remediation: well ID
10. Oil Field Water Supply: lease
11. Test Hole: well ID
12. Geothermal: how many bores?
13. Other (specify):

Was a chemical/bacteriological sample submitted to KDHE? Yes No
Water well disinfected? Yes No

8 TYPE OF CASING USED: Steel PVC Other
Casing diameter 4 in. to 238 ft., Diameter in. to ft., Diameter in. to ft.
Casing height above land surface 0 in. Weight lbs./ft. Wall thickness or gauge No. SCH-80

TYPE OF SCREEN OR PERFORATION MATERIAL: Steel Stainless Steel PVC Other (Specify)
Brass Galvanized Steel None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE: Continuous Slot Mill Slot Gauze Wrapped Torch Cut Drilled Holes Other (Specify)
Louvered Shutter Key Punched Wire Wrapped Saw Cut None (Open Hole)

SCREEN-PERFORATED INTERVALS: From 218 ft. to 238 ft., From ft. to ft., From ft. to ft.
GRAVEL PACK INTERVALS: From 215 ft. to 238 ft., From ft. to ft., From ft. to ft.

9 GROUT MATERIAL: Neat cement Cement grout Bentonite Other
Grout Intervals: From 0 ft. to 215 ft., From ft. to ft., From ft. to ft.

Nearest source of possible contamination: No potential source of contamination within 200 ft.
Septic Tank Lateral Lines Pit Privy Livestock Pens Insecticide Storage
Sewer Lines Cess Pool Sewage Lagoon Fuel Storage Abandoned Water Well
Watertight Sewer Lines Seepage Pit Feedyard Fertilizer Storage Oil Well/Gas Well
Other (Specify)
Direction from well? Distance from well? ft.

Table with 6 columns: FROM, TO, LITHOLOGIC LOG, FROM, TO, LITHO. LOG (cont.) or PLUGGING INTERVALS. Includes a Notes section.

11 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo-day-year) 06/25/2020 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 914 This Water Well Record was completed on (mo-day-year) 07/21/2020 under the business name of Flint Hills Drilling #914

Form	WWC5
Contractor	Flint Hills Drilling #914
Well Owner	
Doc ID	1524325

Lithology

From	To	LithologicLog
0	5	Surface soil & lt brown lean clay
5	10	Coarse sand
10	15	Fine sand & lean lt brown sandy clay
15	25	Fine sand
25	30	Coarse sand
30	35	Fine sand & lt brown lean clay
35	45	Coarse angular sand
45	55	Lt brown, lean sandy clay w/ fine sand
55	60	Fine sand
60	65	Coarse angular sand
65	70	Coarse sand w/ lt brown lean clay
70	75	Coarse angular sand
75	80	Poorly sorted fine to coarse sand
80	90	Coarse sand & dk tan to red lean clay
90	95	Poorly sorted fine to coarse sand
95	100	Lt brown lean sandy clay w/ fine sand
100	115	Coarse sand w/ lots of caliche
115	125	Angular coarse sand w/ lt brown lean sandy clay

Form	WWC5
Contractor	Flint Hills Drilling #914
Well Owner	
Doc ID	1524325

Lithology

From	To	LithologicLog
125	140	Coarse sand w/ lt brown lean sandy clay
140	145	Fine sand
145	160	Coarse angular sand w/ lean lt brown sandy clay
160	195	Dark red lean sandy clay w/ fine sand
195	240	Fine sand
240	245	Lean sandy red clay w/ fine sand



RAMW-2

RAMW-3

RAMW-1

Commercial

RAMW-5

Residential

MW-5

Residential

Residential

Residential

MW-1

MW-2

MW-4

Commercial

MW-3

Residential

N 1st St

Cosmos Ave

Residential

Residential

N Stanton Ave

Residential

Residential

Residential

County Road B

County Road B

N 2nd St

N Stevens Ave

N Stevens Ave

St St