

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

PHILLIPSBURG NORTH

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Phillips		Fraction SE 1/4 SE 1/4 SW 1/4		Section number 4	Township number T 3 S R	Range number 18 - W XX
2. Distance and direction from nearest town or city: 3mi. North & 1 1/2 west of Phillipsburg				3. Owner of well: Clyde Runion R.R. or street: RR City, state, zip code: Phillipsburg, Ks. 67661		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 1/2 in. Completion date 11-18-78 Well depth 61 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From		To		9. Casing: Material Plastic Height: Above ground Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 6 in. to 61 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. Sch 200
Top Soil		0		1		10. Screen: Manufacturer's name _____ Western Type PVC Dia. 6" Slot/gauze 1/8" Length 10' Set between 51 ft. and 61 ft. ft. and _____ ft. Gravel pack? Yes Size range of material 4" minus
Lt. Brown Clay (loose)		1		45		11. Static water level: _____ mo./day/yr. 51 ft. below land surface Date 11-18-78
Fine Sand		45		55		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ 14 g.p.m.
Coarse Sand & Gravel		55		59		13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
Shale		59		61		14. Well head completion: <input type="checkbox"/> Pitless adapter 2 1/2 inches above grade
10' g		51		8 1/2		15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
12		59		19 5/8		16. Nearest source of possible contamination: ft. 50' Direction SW Type Sept. Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
17		59		19 5/8		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Deer Drilling 344 Business name Phillipsburg, Ks. 67661 Address _____ Signed William D. Deer Date 11-27-78 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer will complete well				

3 18 4
 Sec
 1/4 SE SE SW
 1/4 SE SE SW