

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

PHILLIPSBURG NORTH  
WATER WELL RECORD  
KSA 82a-1201-1215

318W 36E 3E  
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Phillips</b>	Township name <b>Phillipsburg NE SE NE</b>	Fraction	Section number <b>36</b>	Town number <b>T-3-S</b>	Range number <b>R-18-W</b>
Distance and direction from nearest town or city: <b>1 mile of Phillipsburg EAST</b>				3 Owner of well: <b>Mrs Roy Ferguson Phillipsburg Kansas</b>		
Street address of well location if in city:				Address:		
Locate with "X" in section below:		Sketch map:		4 Well depth: <u>80</u> ft. Date of completion <u>5-2-75</u> Well diameter <u>11</u> in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
2		Type and color of material		7 Casing: Material <u>plastic</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>5"</u> Weight <u>200</u> lbs./ft. <u>5'</u> in. to <u>60</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
				8 Screen: Manufacturer <u>Jess &amp; Lowell</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/8</u> Length <u>20'</u> Set between <u>60</u> ft. and <u>80</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>4-1/8</u>		
				9 Static water level: <u>35</u> ft. below land surface Date <u>5-2-75</u>		
				10 Pumping level below land surfaces: <u>30</u> ft. after — hrs. pumping <u>11</u> g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield <u>15</u> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From — ft. to <u>10</u> ft.		
				14 Nearest source of possible contamination: <u>200</u> ft. Direction <u>north</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>red jacket</u> Model number <u>1/2</u> HP <u>1/2</u> Volts <u>230</u> Length of drop pipe <u>65</u> ft. capacity <u>11</u> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Redinger Drilling</u> License No. <u>229A</u> Business name <u>380 St. Phillipsburg, Mo</u> Address <u>Carroll Redinger</u> Date <u>5-28-75</u> Signed <u>Carroll Redinger</u> Authorized representative		

3 18 W 36 NE SE NE