

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County REPUBLIC	Fraction SW 1/4 SE 1/4 NW 1/4	Section number 5	Township number T 3 S	Range number R 2 W
2. Distance and direction from nearest town or city: 2 EAST Street address of well location if in city: BELLEVILLE			3. Owner of well: SYLVIA BLACKBURN R.R. or street: G STREET City, state, zip code: BELLEVILLE, KANS 66935			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date Well depth 160 ft. 4/8/77		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 160 ft. depth; Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 1258
						10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 120 ft. and 130 ft. 150 ft. and 160 ft. Gravel pack? YES Size range of material 4x4
LIMESTONE				0	9	11. Static water level: _____ mo./day/yr. 90 ft. below land surface Date 4/8/77
BROWN CLAY				9	13	12. Pumping level below land surface: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
ROCK				13	15	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
BLUE SHALE				15	82	14. Well head completion: _____ Pitless adapter 12 inches above grade
SHALE W/ SANDROCK				82	99	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
BLUE SHALE				99	173	16. Nearest source of possible contamination: SEPTIC ft. 75 Direction NORTH Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
RED SHALE				173	220	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
STOP				220		
(Use a second sheet if needed)						
18. Elevation: 1530 ft		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX & SONS INC 558 Business name _____ License No. _____ Address CLIFTON KANS 66937 Signed George Cox Date 4/8/77 Authorized representative		

3
 2
 W
 5
 SUSSEMAN
 1/4 1/4 1/4 1/4