

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:		County Norton	Township name Center	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 3	Town number T35	Range number R23W
Distance and direction from nearest town or city:					3 Owner of well: Estes Smith		
Street address of well location if in city: 431 South St					Address: 431 South St Norton Kansas		
Locate with "X" in section below:		Sketch map:		4 Well depth: 59 ft. Date of completion 3/29/75 Well diameter 10 in.			
				<input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
2		Type and color of material		From	To	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
		Clay & Top soil		0	43	7 Casing: Material PVC Height: above Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 59 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 59 ft. depth	
		Sand & Gravel		43	57	8 Screen: Modern Pipe, Inc. Manufacturer Shop Incorporated Type PVC Dia. 5 Slot gauge 1032 Length 15 Set between 43 ft. and 57 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8	
		Blue shale		57	59	9 Static water level: 41 ft. below land surface Date 3/21/75	
		41 16' sat thick				10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 20 g.p.m.	
		in Alluvium				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
						12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 15 ft. to 5 ft.	
						14 Nearest source of possible contamination: ft. 100 Direction SE Type City Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Aeromotor Model number 2012-50P Volts 230 Length of drop pipe 48 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)							
16 Remarks: elevation				17 Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. John R. Fawcett #509 167 Business name License No. Address Box 149 Norton Kans Signed John R. Fawcett Date 3/29/75 Authorized representative			