


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well: County <u>Rawlins</u> Township name <u>Celia</u> Fraction <u>NW 1/4 SE 1/4</u> Section number <u>2</u> Town number <u>3</u> Range number <u>36</u>			
Distance and direction from nearest town or city: <u>4 miles NE of McDonald, Kc.</u> Street address of well location if in city:		3 Owner of well: <u>David Schree</u> Address: <u>Goodland, Kc</u>	
Locate with "X" in section below:  Sketch map:		4 Well depth: <u>259</u> ft. Date of completion <u>6-75</u> Well diameter <u>30</u> in.	
2 Type and color of material		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
		7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Dig. Weight <u>32</u> lbs./ft. <u>1</u> <u>16</u> in. to <u>259</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth	
		8 Screen: <u>911 Brown Entegris</u> Type <u>free flow</u> Dia. <u>10"</u> Slot/gauze <u>3/16</u> Length <u>40'</u> Set between <u>219</u> ft. and <u>259</u> ft. Fittings: <u>3/4"</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ___	
9 Static water level: <u>170</u> ft. below land surface Date <u>6-75</u>		10 Pumping level below land surfaces: <u>240</u> ft. after <u>24</u> hrs. pumping <u>450</u> g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield <u>800</u> g.p.m.	
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___		12 Well head completion: <u>12"</u> <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <u>Buddley</u> <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Clay Depth: From <u>0</u> ft. to <u>10</u> ft.		14 Nearest source of possible contamination: ft. ___ Direction <u>West</u> Type ___ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
15 Pump: Manufacturer's name <u>Western Sand Roller</u> Model number <u>10C</u> HP <u>100</u> Volts <u>440</u> Length of drop pipe <u>250</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Jack Poore Drilling</u> 197 Business name License No. Address <u>McDonald, Kc</u> Signed <u>Jack Poore</u> Date <u>7-15-75</u> Authorized representative	
16 Remarks: elevation <u>3216 (TOPO)</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			