

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

DCC

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Township - Celia

1. Location of well:		County Rawlins	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 18	Township number T 3 S	Range number R 36	W
2. Distance and direction from nearest town or city: 1 1/2 miles West on HWY. 36 on North side of road				Owner of well: L.C. Bell R.R. or street: City, state, zip code: McDonald, Kansas 67745			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: 6. Bore hole dia. 30 in. Completion date Well depth 318 ft. 1/28/76 7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary 8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material Steel Height: Above + Below Threaded Welded X Surface 12 in. RMP PVC Weight lbs./ft. Dia 16 in. to 208 ft. depth Wall Thickness: inches or Dia. in. to ft. depth Gauge No. 0.188 10. Screen: Manufacturer's name Brown 10' Cook Type Regular Dia. 16" Slot/gauze 10% Length 100' Set between 208 ft. and 308 ft. 308 ft. and 318 ft. Gravel pack? X Size range of material 1/2 X 5/8 0% #1 11. Static water level: 200' ft. below land surface Date 01-29-76 12. Pumping level below land surfaces: 310 ft. after 2 hrs. pumping 1230 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1230 g.p.m. 13. Water sample submitted: mo./day/yr. Yes X No Date 14. Well head completion: Pitless adapter 12 inches above grade 15. Well grouted? X With: Neat cement X Bentonite X Clay Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: ft. mile Direction West Type Farm Well disinfected upon completion? Yes X No 17. Pump: Manufacturer's name Floway 2-23-76 Model number 7622 HP 100 Volts Length of drop pipe 280 ft. capacity g.p.m. Type: 14 stage 10" poH bowl Submersible X Turbine Jet Reciprocating Centrifugal Other			
5. Type and color of material				From	To		
Top soil				0	200		
Clay				200	206		
Medium to coarse sand & gravel				206	229		
Clay & traces of sand stone				229	239		
Medium to coarse sand				239	243		
Clay				243	252		
Medium to coarse sand & gravel				252	265		
Medium to coarse sand & gravel & cement streaks				265	269		
Medium to coarse sand				269	280		
Coarse sand & gravel				280	289		
Coarse sand & gravel & clay streaks				289	300		
Fine to medium sand				300	309		
Fine to medium sand & layers of clay				309	317		
Ochre & Shale				317	330		
BROCK 317'							
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well and Pump 245 Business name License No. Address PO Box 852 Colby, Ks. Signed Sally Berry 3/22/77 Date Authorized representative			
Topography: Hill Slope X Upland Valley							