


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Republic</u>	Fraction <u>SW 1/4 SW 1/4 NW 1/4</u>	Section number <u>17</u>	Township number <u>T 3 S</u>	Range number <u>R 4 W</u>
2. Distance and direction from nearest town or city: <u>1 MILE WEST OF SCANDIA</u>			3. Owner of well: <u>Robert Larson</u>			
Street address of well location if in city:			R.R. or street: <u>—</u>			
4. Locate with "X" in section below:			City, state, zip code: <u>Scandia, Kansas 66966</u>			
<div>Sketch map: </div>			6. Bore hole dia. <u>36</u> in. Completion date <u>6/30/76</u> Well depth <u>51</u> ft.			
5. Type and color of material			7. <u>—</u> Cable tool <u>—</u> Rotary <u>—</u> Driven <u>—</u> Dug <u>—</u> Hollow rod <u>—</u> Jetted <u>—</u> Bored <u>X</u> Reverse rotary			
Topsoil & Sand			8. Use: <u>—</u> Domestic <u>—</u> Public supply <u>—</u> Industry <u>X</u> Irrigation <u>—</u> Air conditioning <u>—</u> Stock <u>—</u> Lawn <u>—</u> Oil field water <u>—</u> Other			
Fine & coarse sand some gravel			9. Casing: Material <u>A-C</u> Height: Above or below Threaded <u>—</u> Welded <u>—</u> Surface <u>12</u> in. RMP <u>—</u> PVC <u>—</u> Weight <u>34</u> lbs./ft.			
Blue fine sand Coarse sand & gravel			Dia. <u>16</u> in. to <u>51</u> ft. depth Wall Thickness: inches <u>—</u> Dia. <u>—</u> in. to <u>—</u> ft. depth <u>—</u> in. <u>0.75</u>			
Blue fine sand			10. Screen: Manufacturer's name <u>Johnson</u> <u>Concrete</u>			
Med. Sand & gravel (med. Blue)			Type <u>A-C</u> Dia. <u>16</u> in.			
Slabs of rock			Slot/gauze <u>125</u> Length <u>26</u>			
Coarse sand & gravel			Set between <u>25</u> ft. and <u>51</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/4" to 1/2"</u>			
Clay			11. Static water level: <u>10</u> ft. below land surface Date <u>6/25/76</u>			
Waterworn limerock gravel			12. Pumping level below land surfaces: <u>31</u> ft. after <u>1</u> hrs. pumping <u>800</u> g.p.m. <u>35</u> ft. after <u>15</u> hrs. pumping <u>900</u> g.p.m. Estimated maximum yield <u>900</u> g.p.m.			
Clay			13. Water sample submitted: <u>—</u> mo./day/yr. <u>—</u> Yes <u>X</u> No Date <u>—</u>			
Waterworn limerock gravel			14. Well head completion: <u>—</u> Pitless adapter <u>12</u> inches above grade			
Soft blue clay			<u>X</u> Well grouted? <u>Yes</u> With: <u>—</u> Neat cement <u>X</u> Bentonite <u>—</u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
18. Elevation: <u>143</u>			16. Nearest source of possible contamination: <u>House</u> ft. <u>350</u> Direction <u>NW</u> Type <u>sewer</u>			
19. Remarks:			Well disinfected upon completion? <u>—</u> Yes <u>X</u> No			
Topography: <u>—</u> Hill <u>—</u> Slope <u>X</u> Upland <u>—</u> Valley			17. Pump: Manufacturer's name <u>Western Land Roller</u> Model number <u>6m030</u> HP <u>—</u> Volts <u>—</u> Length of drop pipe <u>40</u> ft. capacity <u>900</u> g.p.m. Type: <u>—</u> Submersible <u>X</u> Turbine <u>—</u> Jet <u>—</u> Reciprocating <u>—</u> Centrifugal <u>—</u> Other			
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Shuck Drilling Co.</u> License No. <u>272</u> Address <u>Edgar No. 68935</u> Signed <u>Paul Shuck</u> Date <u>7/5/76</u> Authorized representative			