

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County JEWELL	Fraction SE 1/4 SW 1/4 SE 1/4	Section number 26	Township number T 3 S	Range number R 8 E
2. Distance and direction from nearest town or city: 2 SOUTH		3. Owner of well: HILLS INC			
Street address of well location if in city: MANKATO		R.R. or street: City, state, zip code: MANKATO KANS			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 8 1/2 in. Completion date _____ Well depth 60 ft. 12-20-78		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gauge No. 1258		
			10. Screen: Manufacturer's name _____ PUMPLED Type PVC Dia. 5' Slot gauge 1/16 Length 20' Set between 20 ft. and 40 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/4-1/2"		
			11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 12-20-78		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after N/A hrs. pumping _____ g.p.m. Estimated maximum yield 7 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 50 Direction EAST Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DAVE LLOYD & SONS INC 359 Business name _____ License No. _____ Address ELIOTON KANS 66937 Signed Carol By Date 1-10-79 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T 3
R 8
E 26
S E S W S E
1/4 1/4 1/4