


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County REPUBLIC Fraction SW 1/4 SE 1/4 SE 1/4 Section number 15 Township number T 4 S R 1 Range number 1	
2. Distance and direction from nearest town or city: 1 1/2 E 1 S Street address of well location if in city: AGENDA	
3. Owner of well: BILL PACKARD R.R. or street: RR City, state, zip code: AGENDA, KANS 66930	
4. Locate with "X" in section below: Sketch map: 	
5. Type and color of material	
	From To
TOPSOIL	0 3
BROWN CLAY	3 27
SANDY CLAY	27 31
BROWN CLAY	31 41
RED CLAY	41 45
SANDROCK	45 51
RED CLAY	51 56
SANDROCK	56 63
BLUE CLAY	63 70
RED CLAY	70 100
STOP	100
(Use a second sheet if needed)	
18. Elevation: 1400 ft	19. Remarks:
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
6. Bore hole dia. 2 in. Completion date _____ Well depth 100 ft. 9-23-78	
7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material PVC Height 0 above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 2 in. to 100 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258	
10. Screen: Manufacturer's name _____ PUMPCO Type PVC Dia. 5" Slot gauze 1/16" Length 30' Set between 450 ft. and 6020 ft. 90 ft. and 100 ft. Gravel pack? YES Size range of material 20x40	
11. Static water level: _____ mo./day/yr. 50 ft. below land surface Date 9-23-78	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after N/A hrs. pumping _____ g.p.m. Estimated maximum yield 6 g.p.m.	
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 12 ft.	
16. Nearest source of possible contamination: _____ ft. 400 Direction EAST Type LATE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DARYL COX + SONS INC 359 Business name License No. _____ Address CLIFTON, KANS 66937 Signed Daryl Cox Date 9-25-78 Authorized representative	

T 4 S R 1 SE 1/4 1/4 1/4