

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County SMITH Fraction SE 1/4 SE 1/4 SE 1/4 Section number 2 Township number T 4 S R 14 Range number EW

2. Distance and direction from nearest town or city: 4 W 3 S of Smith center
Street address of well location if in city: Smith center
3. Owner of well: Harold Cornwell
R.R. or street: Smith center KS.
City, state, zip code:

4. Locate with "X" in section below: Sketch map:
N
W E
S
1 Mile

draw 100 ft
well
drainage

6. Bore hole dia. 8 in. Completion date 6-21-76
Well depth 70 ft.
7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary
8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other
9. Casing Material Steel Pipe Height: (Above or below)
Threaded Welded Surface 14 in.
RMP PVC Weight lbs./ft.
Dia. 5 in. to 20 ft. depth Wall Thickness: inches or
Dia. in. to ft. depth gage No. 200

5. Type and color of material	From	To
Top soil & clay	0	18
Sandy clay	18	45
Clay blue	45	55
broken rocks	55	60
Shale	60	70

10. Screen: Manufacturer's name Jess & Howell
Type slotted Pipe Dia. 5 1/2
Slot/gauze 0.30 Length 10'
Set between 50 ft. and 60 ft.
 ft. and ft.
Gravel pack? yes Size range of material fine to 3/8
11. Static water level: 27 ft. below land surface Date 6-21-76 mo./day/yr.
12. Pumping level below land surface unknown air develop.
 ft. after hrs. pumping 5 g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield 20+ g.p.m.
13. Water sample submitted: mo./day/yr.
Yes No Date
14. Well head completion: 14 inches above grade
 Pitless adapter
15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 15 ft.
16. Nearest source of possible contamination: draw
ft. 100 Direction 0 Type draw
Well disinfected upon completion? Yes No
17. Pump: Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation:
Topography:
 Hill
 Slope
 Upland
 Valley
19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
MARVIN Well Drilling Co
Business name License No.
Address Red Cloud Ne
Signed Levy Marvin Date 2-3-77
Authorized representative