

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Phillips	Township name Solomon	Fraction E 1/4 NW 1/4	Section number 26	Town number 4	Range number 18
Distance and direction from nearest town or city: South of Gladewater, Kan				3 Owner of well: CITY OF PHILLIPSBURG		
Street address of well location if in city:				Address: Phillipsburg, Kan		
Locate with "X" in section below: N W E S 1 Mile		Sketch map:		4 Well depth: 66 ft. Date of completion 5-22-76 Well diameter 28 in.		
2 Type and color of material		From To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				X Casing: Material 5-3 Height: above/below X 2 1/2 in. Dia. <input type="checkbox"/> Surface 48 in. Diam. 1 1/2 in. to 1 1/2 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
				X Screen: Manufacturer Johnson Casings Type Cement Dia. 1 1/2 Slot/gauze 3/16 Length 13' Set between 3 1/2 ft. and 6 1/2 ft. Fittings: 3 1/2 to 5 1/2 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material —		
				X Static water level: 25 ft. below land surface Date 5-22-76		
16 Remarks: elevation		(use a second sheet if needed)		10 Pumping level below land surfaces: 66 ft. after 6 hrs. pumping 800 g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 800 g.p.m.		
				11 Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date —		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 20 ft.		
				14 Nearest source of possible contamination: acospa ft. 2800 Direction E Type — Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DLH Drilling Co. 303 Business name License No. Address 304 368 Hill City, Kan Signed Allen Dorman Date 5-24-76 Authorized representative		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Mfg Model number 6 M HP 40 Volts 480 Length of drop pipe 70 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
				16 Remarks: elevation		
				Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
				Forward the white, blue and pink copies to the Kansas State Dept. Of Health.		
				Form WWC-5		