


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

LOGAN
ABWS
1-23-80

1. Location of well:		County PHILLIPS	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 33	Township number T 4 S	Range number R 20 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: Irreg. Track 2119 & part of 1341				3. Owner of well: City of Logan R.R. or street: City, state, zip code: Logan, Kansas 67646		
4. Locate with "X" in section below:  Sketch map:				6. Bore hole dia. 24 in. Completion date 9-12-76 Well depth 57 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 12 in. to 57 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 160		
10. Screen: Manufacturer's name Carlson Type PVC Dia. 12" Slot/gauze 1/8 Length 12' Set between 45 ft. and 57 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 to 1/4"				11. Static water level: <input type="checkbox"/> mo./day/yr. 38 ft. below land surface Date 9-12-76		
12. Pumping level below land surfaces: 50 ft. after 8 hrs. pumping 230 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 300 g.p.m.				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 9-12-76		
14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 15 ft. to 0 ft.		
16. Nearest source of possible contamination: <input type="checkbox"/> ft. 100 Direction W Type Elevator Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Fairbanks Model number <input type="checkbox"/> HP 10 Volts 240 Length of drop pipe 46 ft. capacity 230 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PT's Well Drilling 269A Business name Palco, Kansas License No. Address Palco, Kansas Signed Paul Palco Date 9-15 Authorized representative		
19. Remarks: Well WAS grouted to ground level + City is going to build the building + Run the floor						

4-
20
33
NE 1/4 NE 1/4 NE 1/4