


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Norton	Fraction SW NW SE 1/4 1/4 1/4	Section number 1	Township number T 4 S	Range number R 23 W	E/W
2. Distance and direction from nearest town or city: 7 South 2 East Street address of well location if in city: of Norton Kans.			3. Owner of well: Duane McEwen R.R. or street: City, state, zip code: Norton Kans 67654				
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map:  1 Mile				6. Bore hole dia. 4 in. Completion date 8/15/79 Well depth 100 ft.
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 275 lbs./ft. Dia. 5 in. to 90 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258				
			10. Screen: Manufacturer's name Modern Pipe Inc Type PVC Dia. 5" Slot 1.032 Length 10' Set between 90 ft. and 100 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 5 x 1/4				
			11. Static water level: <input type="checkbox"/> mo./day/yr. 54 ft. below land surface Date 8/15/79				
(Use a second sheet if needed)			12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.				
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>				
			14. Well head completion: Cement platform <input type="checkbox"/> Pitless adapter 10 Inches above grade				
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.				
			16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: Manufacturer's name Aermator Mill Model number 81 HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 90 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Fawcett & Son D.L.G. 167 Business name License No. Address Norton Kans 67654 Signed John A. Fawcett Date 8/25/79 Authorized representative				
			19. Remarks: Cased to 100' 2315. Back-filled 45'				