

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CIA

1. Location of well: County **Norton** Fraction **NE 1/4 NE 1/4 SW 1/4** Section number **2** Township number **4** Range number **25W** E/W

2. Distance and direction from nearest town or city: **3 miles east 1 south of Clayton, Kansas**
Street address of well location if in city: _____
3. Owner of well: **David Ward**
R.R. or street: **Clayton, Kansas 67629**
City, state, zip code: _____

4. Locate with "X" in section below: Sketch map:

N	
NW	NE
SW	SE
S	

Garage []

House []

Abandoned Farmstead

X well

105'

Barn & Lots

Drain Slope →

1 Mile

6. Bore hole dia. **9** in. Completion date _____
Well depth **70** ft. **11/7/75**

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material **Pl.** Height: Above or below _____
Threaded Welded Surface **12** in.
RMP PVC Weight **180** lbs./ft.
Dia. **5** in. to **60** ft. depth; Wall Thickness: inches or _____
Dia. _____ in. to _____ ft. depth; gage No. **250**

5. Type and color of material

From	To
Fine sandy clay	0 25
Lime rock and fine sand	25 30
Sandy clay (brown)	30 96
Shale (yellow)	96 100
	96
	42
	54' sat well
	in of

10. Screen: Manufacturer's name **Modern Pipe Inc.**
Type **PVC** Dia. **5**
Slot/gauze **Slot** Length **10**
Set between **60** ft. and **70** ft.
_____ ft. and _____ ft.
Gravel pack Size range of material **1/2" & 1/8"**

11. Static water level: _____ mp./day/yr.
42 ft. below land surface Date **10/28/75**

12. Pumping level below land surfaces:
46 ft. after **1** hrs. pumping **10** g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield **20** g.p.m.

13. Water sample submitted: _____ mo./day/yr.
Yes No _____ Date _____

14. Well head completion: Pitless adapter **12** inches above grade

15. Well grouted? **yes**
With: Neat cement Bentonite _____ Concrete _____
Depth: From **4** ft. to **16** ft.

16. Nearest source of possible contamination:
ft. **100** Direction **NE** Type **Barn**
Well disinfected upon completion? _____ Yes No _____

17. Pump: _____ Not installed
Manufacturer's name **Unknown**
Model number _____ HP **1/2** Volts **115**
Length of drop pipe **60** ft. capacity **6** g.p.m.
Type: _____ Submersible _____ Turbine
 Jet _____ Reciprocating
_____ Centrifugal _____ Other _____

18. Elevation: _____ Topography: _____ Hill _____
 Slope _____ Upland _____ Valley _____

19. Remarks: **Could not find the sewer of this unused house.**
2435 (TUPO)
2337

20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
John R. Fawcett & Xon 167
Business name _____ License No. _____
Address **Norton, Kansas 67654**
Signed **John R. Fawcett** Date **11/24/75**
Authorized representative

T-4
R-25
S-2
NE NE SW
1/4 1/4 1/4 1/4