

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CSE

| | | | | | |
|----------------------|--------------------------|---|-----------------------------|---------------------------------|-----------------------------|
| 1. Location of well: | County Decatur | Fraction SW 1/4 SE 1/4 SW 1/4 | Section number 29 | Township number T 4 S | Range number R 27 |
|----------------------|--------------------------|---|-----------------------------|---------------------------------|-----------------------------|

| | |
|---|---|
| 2. Distance and direction from nearest town or city: 3 miles South; 2 miles West Street address of well location if in city: | 3. Owner of well: Sylvester Ritter R.R. or street: City, state, zip code: Dresden, KS 67655 |
|---|---|

4. Locate with "X" in section below: Sketch map:

N

S

6. Bore hole dia. 24 in. Completion date _____
Well depth 69 ft. 5-13-78

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material Steel Height: Above or below
Threaded Welded Surface 12 in.
RMP PVC Weight _____ lbs./ft.
Dia. 12 in. to 69 ft. depth; Wall Thickness: inches or
Dia. _____ in. to _____ ft. depth; gage No. .188

| 5. Type and color of material | From | To |
|--------------------------------|------|----|
| Clay | 0 | 30 |
| Coarse Sand, Clay Streaks | 30 | 44 |
| Clay, Coarse Sand Streaks | 44 | 53 |
| Coarse Sand, Clay Streaks | 53 | 66 |
| Ochre, Shale | 66 | 80 |
| BROCK 66' | | |
| (Use a second sheet if needed) | | |

10. Screen: Manufacturer's name Cook
Type _____ Dia. 12"
Slot/gauze 100 Length 10'
Set between 59 ft. and 69 ft.
_____ ft. and _____ ft.
Gravel pack? yes Size range of material 30% #1 0%

11. Static water level: 25 ft. below land surface Date 5-15-78
^{1/2} mo./day/yr.

12. Pumping level below land surfaces:
63 ft. after 2 hrs. pumping 495 g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 495 g.p.m.

13. Water sample submitted: _____ mo./day/yr.
Yes No Date _____

14. Well head completion:
 Pitless adapter 12 Inches above grade

15. Well grouted? _____
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 1,500 Direction East Type Farmstead
Well disinfected upon completion? Yes No

17. Pump: _____ Not installed
Manufacturer's name Floway
Model number 10 DOI HP 25 Volts 460
Length of drop pipe 60 ft. capacity 400 g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

| | |
|---|--------------|
| 18. Elevation: | 19. Remarks: |
| Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | |

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Western Well and Pump, Inc. 24

Business name _____ License No. _____
Address 1100 So Range Colby, KS
Signed Roy E. Senior, Inc. Date 5-31-78
Authorized representative Roy Senior

T 4 R 27 W 29 S 1/4 SE SW