

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DCC

1. Location of well:		County DeCATUR	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 10	Township number T 4 S	Range number R 29 E (W)
2. Distance and direction from nearest town or city: 75 1/2 W Oberlin			3. Owner of well: Circle W Inc R.R. or street: City, state, zip code: Oberlin, Kans 67749			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9" in. Completion date 11-28-76 Well depth 135 ft.		
		<p>7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p>		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Plstc Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 92 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5" in. to 135 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
5. Type and color of material				From	To	10. Screen: Manufacturer's name Jess & Lowell Superior Well Casing Type Rmp Dia. 5" Slot/gauze 1/16 Length 135 ft. Set between 135 ft. and 135 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-3/4
Topsoil				0	19	11. Static water level: 113 ft. below land surface Date 11-9-76 mo./day/yr.
Clay				19	38	12. Pumping level below land surfaces: N/A ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Sand FAER				38	51	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date
Clay				51	76	14. Well head completion: Pitless adapter 12 inches above grade
sand fine with clay				76	94	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.
Limestone				94	98	16. Nearest source of possible contamination: 190 ft. Direction west Type Arch Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Clay streaks limestone				98	110	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Sand with clay				110	134	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Jedden Pfeiffer 339 Business name Jedden Kans. License No. Address St. Wagoner Signed St. Wagoner Date 11-26-76 Authorized representative
Sand fine				134	141	
Clay white				141	147	
Sand medium				147	153	
Shale yellow okar				153	155	
BROCK 153'						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 7
R 29
W
T
O
SW
SE
1/4 1/4 1/4 1/4