

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BAA

1. Location of well: County <u>RAWLINS</u>		Fraction <u>NE 1/4 NE 1/4 NW 1/4</u>		Section number <u>10</u>		Township number T <u>4</u> S <u>35</u> E/W		Range number	
2. Distance and direction from nearest town or city: <u>8 miles East</u>		3. Owner of well: <u>RENO FIDIAN</u>		Street address of well location if in city: <u>5 South of McDonald</u>		R.R. <u>none</u>		City, state, zip code: <u>McDonald, Kan.</u>	
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8"</u> in. Completion date <u>Drilled</u>		Well depth <u>242</u> ft. <u>3/16/78</u>		7. <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	
				<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From		To		9. Casing: Material <u>PVC</u> Height: Above or below		Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in.	
<u>Top Soil</u>		<u>0</u>		<u>3</u>		RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u> </u> lbs./ft.		Dia. <u>5</u> in. to <u>242</u> ft. depth Wall Thickness: inches or	
<u>clay slick Lt Brown</u>		<u>3</u>		<u>65</u>		Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>214</u>		10. Screen: Manufacturer's name <u>SPR 26</u>	
<u>Fine sand Brown</u>		<u>65</u>		<u>95</u>		Type <u>PVC</u> Dia. <u>5"</u>		<u>MPI 1120 MSE PW</u>	
<u>Rock soft white</u>		<u>95</u>		<u>100</u>		Slot/gauze <u> </u> Length <u>10'</u>		Set between <u>232</u> ft. and <u>242</u> ft.	
<u>Clay - sand - Rock</u>		<u>100</u>		<u>190</u>		Gravel pack? <u>yes</u> Size range of material <u>1/4 to 1/2</u>		11. Static water level: <u>200</u> ft. below land surface Date <u>3/16/78</u>	
<u>Rock Hard Red</u>		<u>190</u>		<u>200</u>		12. Pumping level below land surfaces:		<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
<u>Sand Fine Brown</u>		<u>200</u>		<u>230</u>		13. Water sample submitted: <u> </u> mo./day/yr.		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
<u>Sand Fine some coarse Brown</u>		<u>230</u>		<u>240</u>		14. Well head completion:		<input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
<u>Shale slick Gray & yellow</u>		<u>240</u>		<u>242</u>		15. Well grouted? <u>yes</u>		With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>5</u> ft. to <u>15</u> ft.	
<u>BROCK 240'</u>						16. Nearest source of possible contamination:		ft. <u>160</u> Direction <u>South</u> Type <u>SEPT TANK</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed		20. Water well contractor's certification:	
						Manufacturer's name <u>HA Drilling</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
						Model number <u> </u> HP <u> </u> Volts <u> </u>		<u>331</u> License No.	
						Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.		Business name <u>HA Drilling</u>	
						Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		Address <u>RR 2 Atwood Kan.</u>	
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		Signed <u>Harry A. Beatty</u> Date <u>4/2/78</u>	
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		Authorized representative	
18. Elevation:		19. Remarks:							
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley									

T-4
 R-35
 E-W
 Sec-10
 NE NE NW
 1/4 1/4