

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

~~500~~ BDC

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620


1 Location of well:	County <u>Cheyenne</u>	Township name <u>Alexander</u>	Fraction <u>SE 1/4 of NW 1/4</u>	Section number <u>27</u>	Town number <u>4</u>	Range number <u>37</u>
---------------------	------------------------	--------------------------------	----------------------------------	--------------------------	----------------------	------------------------

Distance and direction from nearest town or city:
5 miles SE of Bird City, Ks
Street address of well location if in city:

3 Owner of well: Gene Pinalto
Address: Bird City, Ks

Locate with "X" in section below:

Sketch map:



4 Well depth: 266 ft. Date of completion 6-75
Well diameter 16 in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry
☒ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well

7 Casing: Material Steel Height: above/below
Threaded ☐ Welded ☐ Surface 12 in.
Dig. Weight 22 lbs./ft. L
16 in. to 266 ft. depth Drive shoe? ☐ Yes ☒ No
in. to ft. depth

8 Screen: Manufacturer W.G. Brown Enterprise
Type fine flow Dia. 16"
Slot gauge 3/16 Length 40'
Set between 256 ft. and 266 ft.
Fittings: 3/4"
Gravel pack ☒ Yes ☐ No Size range of material

9 Static water level:
155 ft. below ground surface Date 6-75

10 Pumping level below land surfaces:
240 ft. after 70 hrs. pumping 1000 g.p.m.
ft. after hrs. pumping g.p.m.
Estimated maximum yield 1000 g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date

12 Well head completion: 12"
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☒ Yes ☐ No Gravelly clay
☐ Neat cement ☐ Bentonite
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination:
ft. Direction Type
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☐ Not installed
Manufacturer's name Grundfos
Model number 12545 HP 1 Volts 115
Length of drop pipe 266 ft. capacity 1000 g.p.m.
Type:
☐ Submersible ☒ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

2	Type and color of material	From	To
	top soil + clay	0	130
	10' gravel	130	140
	1' gravel 4' hard porous rock 5' porous rock	140	150
	2' hard porous rock, 8' loose porous rock little clay	150	160
	3' rock 7' porous rock little clay	160	170
	10' porous rock	170	180
	3' porous rock 7' rock	180	190
	2' rock 8' loose porous rock	190	200
	4' loose porous rock 6' gravel	200	210
	10' gravel	210	220
	10' sand and gravel	220	230
	2' gravel 3' porous rock 5' gravel	230	240
	7' clay 3' gravel strips of sandy clay	240	250
	3' rock 7' gravel	250	260
	3' gravel 3' shale	260	266
	(use a second sheet if needed)		

16 Remarks: elevation

Topography:

- ☐ Hill
☐ Slope
☒ Upland
☐ Valley

17 Water well contractor's certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Jack Bone Drilling 197
Business name License No.
Address McDonald Ks
Signature Jack Bone Date 7-15-75
Authorized representative