


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <u>Cherokee</u>	Township name <u>SE-NW 1/4</u>	Fraction <u>1/4</u>	Section number <u>29</u>	Town number <u>4</u>	Range number <u>37</u>
Distance and direction from nearest town or city: <u>5 South of Bird City Kan. 1 1/2 East</u>				3 Owner of well: <u>Lynn Glasco</u> Address: <u>Bird City, KS.</u>		
Locate with "X" in section below: N  W S 1 Mile				Sketch map:		
2				4 Well depth: <u>245</u> ft. Date of completion <u>July</u> Well diameter <u>8</u> in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
From To				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Top Soil				7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>8</u> in. to <u>245</u> ft. depth Weight <u>    </u> lbs./ft. <u>    </u> Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Yellow Clay				8 Screen: Manufacturer <u>J &amp; L</u> Type <u>SLT</u> Dia. <u>5"</u> Slot/gauze <u>    </u> Length <u>10 FT</u> Set between <u>235</u> ft. and <u>245</u> ft. <u>    </u> Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>    </u>		
White Sandy Clay				9 Static water level: <u>160</u> ft. below land surface Date <u>July 1</u>		
Sand - Clay SR				10 Pumping level below land surfaces: <u>    </u> ft. after <u>    </u> hrs. pumping <u>    </u> g.p.m. <u>    </u> ft. after <u>    </u> hrs. pumping <u>    </u> g.p.m. Estimated maximum yield <u>    </u> g.p.m.		
Rock				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>    </u>		
Sand - Clay SR				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Rock				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.		
Sand - Clay				14 Nearest source of possible contamination: ft. <u>    </u> Direction <u>    </u> Type <u>    </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Rock				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>    </u> Model number <u>    </u> HP <u>    </u> Volts <u>    </u> Length of drop pipe <u>    </u> ft. capacity <u>    </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand - Clay SR				16 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Schrenager &amp; Sons 1849</u> Business name <u>    </u> License No. <u>    </u> Address <u>    </u> Signed <u>    </u> Date <u>    </u> Authorized representative		
BROCK ?				17		
(use a second sheet if needed)						
16 Remarks: elevation <u>3355 (TOPO)</u>						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						