USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T	R	EW	sec 1/4	1/4	1/4	No.

WATER WELL RECORD
KSA 82a-1201-1215

BCB

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well: County	Township name	Fraction	Section number	Town number	Range number
Cheyenne	NW-SW	NW 1/4	15	4	39

Distance and direction from nearest town or city: 3 so. Wheeler 1 East 1/4 South
Street address of well location if in city:

3 Owner of well: Lavern Ball
Address: St. Francis, KS

Locate with "X" in section below: Sketch map:

N
W E
S
1 Mile

4 Well depth: 260 ft. Date of completion 7-16-73
Well diameter 8 in.

5 ☐ Cable tool ☒ Rotary ☒ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry
☐ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐

7 Casing: Material Hyrea Height: above/below
Threaded ☐ Welded ☐ Surface 12 in.
Diam. 8 in. to 260 ft. depth Weight ___ lbs./ft.
___ in. to ___ ft. depth Drive shoe? ☐ Yes ☐ No

2

Type and color of material	From	To
Top Soil	0	2
Sandy Clay	2	13
Rock	13	15
Sand - SR - Clay	15	30
Sand - Clay	30	53
Rock	53	54
Sand - SR - Clay	54	81
Rock	81	82
SR - Sand - Clay	82	110
Rock	110	111
Sand - Gravel - Clay	111	130
Clay - SR - Sand	130	140
Rock	140	141
Sand + Gravel - Clay	141	170
Clay - SR	170	186
Rock	186	187
Sand + Gravel - Clay Br.	187	215
Rock	215	216
Sand + Gravel - Clay	216	229
Rock	229	230
Sand + Gravel - Clay	230	259
Shale	259	260

(use a second sheet if needed)

BROCK 259'

8 Screen:
Manufacturer J+L
Type SLOT RMP Dia. 5"
Slot/gauze ___ Length 10 ft
Set between 250 ft. and 260 ft.
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material 1/8

9 Static water level:
160 ft. below land surface Date ___

10 Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date ___

12 Well head completion:
☐ Pitless adapter ☐ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐ ___
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination:
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☒ Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe 240 ft. capacity ___ g.m.p.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation

Topography:
☐ Hill
☐ Slope
☐ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Schennings Drilling Co. 1849
Business name License No.
Address St. Francis, KS.
Signed [signature] Date 7-20-73
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5