

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <i>Republic</i>	Fraction <i>SW 1/4 NW 1/4 SW 1/4</i>	Section number <i>27</i>	Township number T <i>4</i> S	Range number R <i>4</i> E <i>(N)</i>																					
2. Distance and direction from nearest town or city: <i>1/2 E - 1 3/4 S</i>			3. Owner of well: <i>Robert Carlgren</i>																							
Street address of well location if in city: <i>of Norway, Ks</i>			R.R. or street: <i>#2</i>																							
			City, state, zip code: <i>Concordia, Ks 66901</i>																							
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <i>32</i> in. Completion date Well depth <i>56</i> ft. <i>5-26-77</i>																						
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																						
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																						
5. Type and color of material		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td><i>top soil</i></td> <td><i>0</i></td> <td><i>14</i></td> </tr> <tr> <td><i>sand</i></td> <td><i>14</i></td> <td><i>23</i></td> </tr> <tr> <td><i>gravel</i></td> <td><i>23</i></td> <td><i>28</i></td> </tr> <tr> <td><i>fair green gravel</i></td> <td><i>28</i></td> <td><i>32</i></td> </tr> <tr> <td><i>gravel + clay</i></td> <td><i>32</i></td> <td><i>36</i></td> </tr> <tr> <td><i>good gravel</i></td> <td><i>36</i></td> <td><i>56</i></td> </tr> </tbody> </table>			From	To	<i>top soil</i>	<i>0</i>	<i>14</i>	<i>sand</i>	<i>14</i>	<i>23</i>	<i>gravel</i>	<i>23</i>	<i>28</i>	<i>fair green gravel</i>	<i>28</i>	<i>32</i>	<i>gravel + clay</i>	<i>32</i>	<i>36</i>	<i>good gravel</i>	<i>36</i>	<i>56</i>	9. Casing: Material <i>AC</i> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <i>12</i> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <i>34</i> lbs./ft. Dia. <i>16</i> in. to <i>56</i> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <i>74</i>	
					From	To																				
<i>top soil</i>	<i>0</i>	<i>14</i>																								
<i>sand</i>	<i>14</i>	<i>23</i>																								
<i>gravel</i>	<i>23</i>	<i>28</i>																								
<i>fair green gravel</i>	<i>28</i>	<i>32</i>																								
<i>gravel + clay</i>	<i>32</i>	<i>36</i>																								
<i>good gravel</i>	<i>36</i>	<i>56</i>																								
		10. Screen: Manufacturer's name <i>Johnson</i> <i>Concrete</i> Type <i>Rebar cement</i> Dia. <i>16"</i> Slot/gauge <i>1/8"</i> Length <i>26'</i> Set between <i>30</i> ft. and <i>56</i> ft. ft. and <input type="checkbox"/> ft. Gravel pack? <i>YES</i> Size range of material <i>1/2 - 1/4"</i>																								
		11. Static water level: mo./day/yr. <i>21</i> ft. below land surface Date <i>5-26-77</i>																								
		12. Pumping level below land surfaces: <i>37</i> ft. after <i>1/2</i> hrs. pumping <i>1250</i> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <i>2000</i> g.p.m.																								
		13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>																								
		14. Well head completion: <input type="checkbox"/> Pitless adapter <i>12</i> inches above grade																								
		15. Well grouted? <i>YES</i> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <i>0</i> ft. to <i>10</i> ft.																								
		16. Nearest source of possible contamination: <i>NONE</i> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																								
		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <i>WLR</i> Model number <i>8M</i> HP <i>30</i> Volts <i>230</i> Length of drop pipe <i>50</i> ft. capacity <i>1300</i> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																								
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>GEO COX + SONS, INC 258</i> Business name License No. Address <i>Clifton Kansas 66937</i> Signed <i>Francis Cox</i> Date <i>10-2</i> Authorized representative																								
18. Elevation: <i>1405'</i>		19. Remarks:																								
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley																										

T-4  
 R-4  
 Sec 27  
 SW 1/4  
 NW 1/4  
 SE 1/4