

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CA4

1. Location of well: County Cheyenne Fraction NE 1/4 NE 1/4 S 1/4 W 1/4 Section number 18 Township number T 4 Range number S R 40 W E/W

2. Distance and direction from nearest town or city: 4 SOUTH 2 1/2 WEST 1/2 S. of ST. FRANCIS
Street address of well location if in city:
3. Owner of well: Warren Northrup
R.R. or street: ST. FRANCIS KANSAS
City, state, zip code: 67756

4. Locate with "X" in section below: Sketch map:
N
W E
S
1 Mile

Stock well

6. Bore hole dia. 5 in. Completion date 10/5/76
Well depth 163 ft.
7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary
8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other
9. Casing: Material PLTS Height: Above or below
Threaded Weld Surface T2 in.
RMP PVC Weight 10 lbs./ft.
Dia. 5 in. to 163 ft. depth Wall Thickness: inches or
Dia. 5 in. to 163 ft. depth gage No. 250

5. Type and color of material	From	To
<u>sandy top soil</u>	<u>0</u>	<u>2</u>
<u>Sandy Clay</u>	<u>2</u>	<u>18</u>
<u>Rock</u>	<u>18</u>	<u>19</u>
<u>SR - Clay</u>	<u>19</u>	<u>24</u>
<u>Rock</u>	<u>24</u>	<u>25</u>
<u>SAND - Clay SR</u>	<u>25</u>	<u>38</u>
<u>Rock</u>	<u>38</u>	<u>40</u>
<u>SR - Clay</u>	<u>40</u>	<u>47</u>
<u>Rock - hd</u>	<u>47</u>	<u>49</u>
<u>SAND - Clay SR</u>	<u>49</u>	<u>87</u>
<u>Rock</u>	<u>87</u>	<u>88</u>
<u>SR - Clay</u>	<u>88</u>	<u>91</u>
<u>Rock</u>	<u>91</u>	<u>92</u>
<u>SR - Clay</u>	<u>92</u>	<u>107</u>
<u>Rock</u>	<u>107</u>	<u>108</u>
<u>SAND & shale - Clay</u>	<u>108</u>	<u>141</u>
<u>Rock</u>	<u>141</u>	<u>142</u>
<u>(Use a second sheet if needed) SAND & shale</u>	<u>142</u>	<u>154</u>

10. Screen: Manufacturer's name JFL
Type slot Dia. 5"
Slot gauze 115 Length 10'
Set between 153 ft. and 163 ft.
Gravel pack? yes Size range of material 1/8"
11. Static water level: 97 ft. below land surface Date 10/8/76 mb./day/yr.
12. Pumping level below land surfaces:
 ft. after hrs. pumping g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield 10 g.p.m.
13. Water sample submitted: mo./day/yr.
Yes No Date
14. Well head completion:
 Pitless adapter 12 inches above grade
15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.
16. Nearest source of possible contamination:
ft. 560 Direction SE Type Septic Tank
Well disinfected upon completion? Yes No
17. Pump: Not installed
Manufacturer's name HP Volts
Model number Length of drop pipe ft. capacity g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: Topography:
 Hill
 Slope
 Upland
 Valley

19. Remarks:
Rock 154-155
Sand & shale 155-162
Shale 162-163
BROCK 162'

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Shreyson Walker, G 1844
Business name St. Francis License No.
Address St. Francis
Signed Shreyson Walker Date 10/14/76
Authorized representative

T 4
R 40 W
E
S
1/4 1/4 1/4
NE 1/4 SW