

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

County	Fraction	Se	ection numbe	r Township number Range number
1. Location of well: Cheyenne	SW 1/4 SW 1/4 S	W1/4	19	T 4 S R 41 E
2. Distance and direction from persons to the		T	of wall -	
2. Distance and direction from nearest town or city:	SW of St. Franc	R.R. or str		frs. Harvey Oschner
Street address of well location if in city: R.R. or street: City, state, zip				Burlington, CO 80807
			, zip code:	6. Bore hole dia. 28 in. Completion date 8-9-78
4. Locate with "X" in section below: Sketch map:				Well depth 34 ft.
,				
j j				7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary
₩				8. Use:Domestic Public supply Industry X Irrigation Air conditioning Stock
				Lawn Oil field water Other
SW SE				9. Casing: Material Steel Height: Above or below
	80 60 CS		3	Threaded
5 50 68				
I → 1 Mile →				Dia. 16in. to 34 ft. depth Wall Thickness: inches or
5. Type and color of material	The state of the s	. [From To	
				10. Screen: Manufacturer's name
100 0011	The second secon		-0 1	I Type wire Dig 16"
Sand & Gravel (Međium)	and the second s		11 2	
Sand & Gravel (Medium)	7. 91/12/		11 2	Set between The State of the St
Coarse Gravel	 РТО ЗАВ. 		20 2	6 Gravel pack? Size range of material
	e de la companya del companya de la companya del companya de la co			
Coarse Gravel & Shale	the content of the section of the content of the section of the content of the co	2 S. 194	26 3	11. Static water level: 12 ft. below land surface Date 8-9-78
	· ·			12. Pumping level below land surfaces:
				- 30 ft. after 2 hrs. pumping 500 g.p.m.
BKOCK SZ'				ft. after hrs. pumping g.p.m.
	<u> </u>			Estimated maximum yield 502 total draw .down
				13. Water sample submitted: mo./day/yr.
				Yes X No Date
				14. Well head completion: Pitless adapter
		i		
				With Negt coment Rentonite X Concrete
				With: Neat cement Bentonite X Concrete Depth: From 0 ft. to 10 ft.
				16. Negrest source of possible contamination:
			<u> </u>	ft. 600 Direction W Type Farmstead
				Well disinfected upon completion? Yes No
				17. Pump: Not installed
				Manufacturer's name <u>WLR</u> Model number <u>10CH</u> HP <u>30</u> Volts
				Length of drop pipe 32 ft. capacity 500g.p.m.
				Type:
				Submersible Turbine
				Jet Reciprocating
(Use a second sheet if needed)				Centrifugal Other
18. Elevation: 19. Remarks:				20. Water well contractor's certification:
				This well was drilled under my jurisdiction and this report
Topography:				is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245
ниі				Business name License No.
Slope				Address Box 852 (Colby, KS 67701 >
Upland				Signed Jucy MacWhina Date & 2012
A Valley 3.				Authorized representative