

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County CLOUD	Fraction C 1/4 SE 1/4 1/4	Section number 12	Township number T 5 S	Range number R 1 W
2. Distance and direction from nearest town or city: 1 EAST			3. Owner of well: DARYL + BARBARA COX		
Street address of well location if in city: 3 NORTH CLYDE			R.R. or street: RR #1		
			City, state, zip code: CLIFTON, KANS 66937		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia 22.3 22 in. Completion date 7-1-77	
				Well depth 223 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material AC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30 lbs./ft. Dia 12 in. to 223 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 24	
5. Type and color of material			From	To	10. Screen: Manufacturer's name JOHNSON CONCRETE
TOPSOIL			0	3	Type AC Dia. 12
BROWN CLAY			3	8	Slot gauge 1/8" Length 45
SANDROCK			8	11	Set between 58 ft. and 223 ft.
RED CLAY			11	15	Gravel pack? Yes Size range of material 4x5
HARD ROCK			15	16	11. Static water level: 120 ft. below land surface Date 7-1-77
RED CLAY			16	28	12. Pumping level below land surfaces: 150 ft. after 2 hrs. pumping 1000 g.p.m.
SANDROCK			28	34	____ ft. after ____ hrs. pumping ____ g.p.m.
BLUE CLAY			34	43	Estimated maximum yield 1000 g.p.m.
SANDROCK			43	45	13. Water sample submitted: ____ mo./day/yr.
BROWN CLAY			45	55	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____
GRAY CLAY			55	119	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
SANDROCK			119	220	15. Well grouted? Yes
STOP			220	223	With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete
BLUE CLAY			220	223	Depth: From 0 ft. to 10 ft.
STOP			223		16. Nearest source of possible contamination: SEPTIC
					ft. 2000 Direction N/E Type TANK
					Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: Not installed
					Manufacturer's name WESTERN LANDR.
					Model number SKB HP 100 Volts ____
					Length of drop pipe 190 ft. capacity 300 g.p.m.
					Type:
					<input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine
					<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
					<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: 1322		19. Remarks:		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
				Geo Cox + Sons Inc 258	
				Business name	
				Address CLIFTON, KANS 66937	
				Signed Daryl Cox Date 7-23-77	
				Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5