

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County SMITH Fraction NE 1/4 NE 1/4 NW 1/4 Section number 18 Township number T 5 S R 13 E Range number 13 E	
2. Distance and direction from nearest town or city: 1-S 1/2 E Street address of well location if in city: OF JAYLORD KAN.	
3. Owner of well: LAWRENCE CONRAD R.R. or street: RR 1 City, state, zip code: JAYLORD KAN. 67638	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. 3 1/4 in. Completion date 7-20-78 Well depth 56 ft.	
7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>	
9. Casing: Material CA Height: Above or below Threaded BAR Welded <input type="checkbox"/> Surface 1 1/4 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/2 in. to 4 3/4 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1"	
10. Screen: Manufacturer's name JOHNSONS Type CASB Dia. 1 1/2 Slot/gauze 1/8 Length 13' Set between 43 ft. and 56 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/4"	
11. Static water level: 18 ft. below land surface Date 7-1-78 mo./day/yr.	
12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 575 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
14. Well head completion: Pitless adapter 14 Inches above grade	
15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 1 ft. to 12 ft.	
16. Nearest source of possible contamination: ft. 50 Direction N Type DITCH Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
17. Pump: Not installed Manufacturer's name Western Food Roller Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 55 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. D & D Service 108 Business name Downs Han License No. Address Wendell DeBee Signed Wendell DeBee Date 8-1-78 Authorized representative	

T 5 R 13 E 18 Sec 1/4 1/4 1/4 NENEHW