

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Cloud	Fraction: NW 1/4 NE 1/4 NE (1/4)	Section number: 31	Township number: T 5 S	Range number: R 2 E
2. Distance and direction from nearest town or city: 4 miles east of Concordia Street address of well location if on road: North side of road			3. Owner of well: Bill Jackson R.R. or street: Rfd #1 City, state, zip code: Concordia, Kansas 66901		
4. Locate with "X" in section below:			Sketch map:		
			<p>6. Bore hole dia. 16 in. Completion date: March 31, 1977 Well depth: 58 ft.</p> <p>7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/></p> <p>9. Casing: Material <input type="checkbox"/> Height: Above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 92 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Di. 16 in. to 58 ft. depth; Wall thickness <input type="checkbox"/> inches or Di. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gauge No. 075</p>		
5. Type and color of material			From	To	
Black soil			1	14	
Fine Sand			15	25	
Gravel			25	58	
Green clay.			59		
					10. Manufacturer's name: Johnson Transite Type: transite Dia. 16 Slot/gauze: 5/32 Length: 13 Set between: 46 ft. and 58 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material: 1/4
					11. Static water level: 24 ft. below land surface Date: 6/2/77
					12. Pumping level below land surfaces: 40 ft. after 1 hrs. pumping 650 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 800 g.p.m.
					13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date: 4/2/77
					14. Well head completion: No Pitless adapter ____ Inches above grade
					15. Well grouted? Yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 7 ft. to 17 ft. / 60 ft.
					16. Nearest source of possible contamination: 1200 ft. Direction: South Type: feed lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: Not installed Manufacturer's name: Western Land Roller Model number 6 HP ____ Volts ____ Length of drop pipe 55 ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Thoman & Son 247 Business name: 2336 16th St Concordia License No. ____ Address: 2336 16th St Concordia Signed: Carl Thoman Date: 6/18/77 Authorized representative
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

1-5-20-31 NW NE NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5